



**Bid No. 25-20**  
**2025 MFT RESURFACING PROJECT**  
**ADDENDUM No. 1**  
**April 28, 2025**

Any and all changes to the Bid are valid only if they are included by written addendum to all potential respondents, which will be emailed prior to the Bid due date to all who are known to have received a complete Bid Document. Each respondent must acknowledge receipt of any addenda by indicating in its Bid. Each respondent, by acknowledging receipt of addenda, is responsible for the contents of the addenda and any changes to the bid therein. Failure to acknowledge receipt of addenda may cause the Bid to be rejected. If any language or figures contained in this addendum are in conflict with the original Bid Document, this addendum shall prevail.

This addendum consists of the following:

1. Addendum No. 1 is attached and consists of a total of two (2) pages including this cover sheet.

Please feel free to call 847-866-2910 or email [lithomas@cityofevanston.org](mailto:lithomas@cityofevanston.org) with any questions or comments.

Sincerely,

Linda Thomas  
Purchasing Specialist



## **Bid No. 25-20**

### **2025 MFT RESURFACING PROJECT**

#### **ADDENDUM No. 1**

**April 28, 2025**

This addendum forms a part of the Bid Documents for Bid #25-20 and modifies these documents. This addendum consists of the following:

**Question:**

Could you please provide a typical section that shows the depths of the proposed level binder and surface.

**Answer:**

Asphalt Surface Course - 2"  
Polymerized Level Binder - 3/4 to 1"