

**2025 Court Improvements: James, Leahy, Ackerman, and Mason  
Parks**

**Bid # 25-24**

**ADDENDUM No. 1**

**April 16, 2025**

Any and all changes to the Contract Document are valid only if they are included by written addendum to all potential respondents, which will be mailed, emailed and/or faxed prior to the bid due date to all who are known to have received a complete bid document. Each respondent must acknowledge receipt of any addenda by indicating on the Bid Form. Each respondent, by acknowledging receipt of any addenda, is responsible for the contents of the addenda and any changes to the bid proposal therein. Failure to acknowledge receipt of any addenda may cause the bid to be rejected. If any language or figures contained in this addendum are in conflict with the original document, this addendum shall prevail.

This addendum consists of the following:

1. Addendum Number One (1) is attached and consists of a total of three (3) pages including this cover sheet. Any changes to the drawings or specifications noted within Addendum Number One (1) will be reflected in subsequent drawing issues.

Please feel free to call (847-866-2910) or email ([lithomas@cityofevanston.org](mailto:lithomas@cityofevanston.org)) with any questions or comments.

Sincerely,

Linda Thomas  
Purchasing Specialist

# 2025 Court Improvements: James, Leahy, Ackerman, and Mason Parks

**Bid # 25-24**

**ADDENDUM No. 1**

**April 16, 2025**

This addendum forms a part of the Specifications and Bid Documents for Bid #25-24 and modifies these documents. This addendum consists of the following:

## **Drawings:**

Sheet D-02

- Fence schedule updated on Detail A to reflect 2" pipe for top and center rail on 10'ht. fence.
- Foundation finishing notes added to Detail A, B, & C
- Conflicting dimension on base of Detail B updated

## **Specifications:**

Change to Specification Section 323113, Chain link Fences and Gates, Part 2.03.A.2


2. Horizontal Framework Members: Intermediate top and bottom rails  
~~according to ASTM F1043.~~
  - a. Round Steel Pipe, Schedule 40
  - b. Size as indicated on drawings

**Note: Acknowledgment of this Addendum is required in the Bid.**

PROJECT NAME:

**2025 COURT IMPROVEMENTS:  
JAMES, LEAHY,  
ACKERMAN, &  
MASON PARKS**

NOTES:



DO NOT SCALE DRAWINGS.  
WHEN PRINTED TO THE  
CORRECT SCALE, THE BOX  
ABOVE MEASURES 1' x 1'.

DRAWING SCALE:

REVISIONS:

1 2025/04/02 - ISSUE FOR BID


1 2025/04/16 - ADDENDUM 1

SHEET TITLE

**DETAILS**

SHEET NO.

**D-02**



**FENCE SCHEDULE**


HEIGHT	FABRIC	TERMINAL POST	LINE POST	TOP RAIL	CENTER RAIL	BOTTOM RAIL	TRUSS ROD W/ TURNBUCKLE	BOTTOM TENSION WIRE
4'-0"	11 GA, 1 3/4" MESH	2 1/2" DIAMETER	2" DIAMETER	1 5/8" DIAMETER	NONE	NONE	NONE	7 GA
10'-0"	11 GA, 1 3/4" MESH	4" DIAMETER	4" DIAMETER	2" DIAMETER	2" DIAMETER	NONE	TERMINAL SECTIONS ONLY	7 GA

NOTE:

- NORTH FENCE TO HAVE ACOUSTIC PANELS INSTALLED PER MANUFACTURER SPECIFICATIONS
- EAST, WEST, AND SOUTH FENCES TO HAVE WINDSCREENS INSTALLED PER MANUFACTURER SPECIFICATIONS


**A VINYL COATED CHAIN LINK FENCING**

NOT TO SCALE




**B DOUBLE SWING GATE**

NOT TO SCALE



**C SINGLE SWING GATE WITH TRANSOM**

NOT TO SCALE



**D EXISTING SWING GATE ADA MODIFICATION**

NOT TO SCALE