

2013 Annual Report

Evanston Utilities Department

Serving the Community for 139 Years



Cover photos, clockwise from top left: cleaning the filters at the Evanston Water Treatment Plant; Evanston Utilities Department divers inspecting one of the City's water intakes in Lake Michigan; installation of a cured-in-place pipe (CIPP) liner in a City sewer main to rehabilitate the pipe; and installation of a 24" diameter water main under Davis Street in conjunction with the 2013 Davis Street reconstruction project.



Table of Contents

Introduction

| | |
|--|----|
| Utilities Department Annual Accomplishments and Performance Measures | 1 |
| Water Treatment Plant Data | 4 |
| Water Treatment Schematic | 5 |
| Water Works Improvements | 6 |
| Service Area and Population | 9 |
| Pumpage to Distribution | 10 |
| Water Revenues | 11 |
| Water Operating and Maintenance Expenses | 12 |
| Employee Profile and Safety | 13 |

Pumping

| | |
|--------------------------------------|----|
| Monthly and Average Daily Pumpage | 15 |
| Annual Pumpage | 16 |
| Average Daily per Capita Consumption | 17 |
| Maximum Day and Peak Hour Pumpage | 18 |
| Maximum Pumpage and Demand Days | 19 |
| Energy Costs | 20 |

Filtration

| | |
|--|----|
| Chemical Treatment: Chemicals Used and Cost | 23 |
| Annual Chemical Costs | 24 |
| Filter Operations | 25 |
| Bacteriological Water Analysis | 26 |
| Taste & Odor, Turbidity, Temperature and Fluoride | 27 |
| Chlorine Residual | 28 |
| pH, Alkalinity and Hardness | 29 |
| Detected Substances: 2013 Water Quality Data | 30 |
| Non-Detected Contaminants: 2013 Water Quality Data | 32 |
| Lead and Copper Statement | 34 |
| Definitions and General Explanations for Use with Water Quality Data | 35 |

Distribution

| | |
|---|----|
| Fire Hydrants: System Data and Maintenance | 37 |
| Valves: System Data and Maintenance | 38 |
| Water Mains: System Data and Maintenance | 39 |
| Water Services: System Data and Maintenance | 40 |
| Breakdown of In-House Maintenance Costs | 40 |
| Water Mains Installed | 41 |
| Cross Connection Control | 42 |

Metering

| | |
|--|----|
| Fixed Network Meter Reading System | 44 |
| Transmitter Tower Locations | 45 |
| Water Meter Inventory | 46 |
| Water Rates to Evanston Customers | 46 |
| Metered Water Services by Category and Water Usage | 47 |
| Water Usage by Evanston Customers | 48 |

Sewer

| | |
|---|----|
| Sewer Revenues | 50 |
| Sewer Operating and Maintenance Expenses | 51 |
| Major Combined Sewer System | 52 |
| Major Relief Sewer System | 53 |
| Major Storm Sewer System | 54 |
| Sewer Mains: System Data and Maintenance | 55 |
| Length of Sewer Mains by Type and Diameter | 56 |
| Sewer Structures: System Data and Maintenance | 57 |
| Breakdown of In-House Maintenance Costs | 58 |
| Sewer Mains Rehabilitated (Lined) | 59 |

Utilities Department Annual Accomplishments and Performance Measures

Introduction

The Utilities Department manages water and sewer operations as well as overseeing other utilities provided to the City of Evanston. The Water Division is responsible for operation and maintenance of the Water Treatment Plant, which supplies water to over 360,000 people in Evanston and five other communities. The Water Division also operates and maintains more than 157 miles of water mains, 2,000 valves, and 1,400 fire hydrants in the Evanston distribution system.

The Sewer Division is responsible for operation and maintenance of the sewer conveyance systems in Evanston, including a combined sewer system, a relief combined sewer system, and a storm sewer system. These systems are comprised of over 200 miles of sewer mains ranging in size from 6-inch diameter to 120-inch diameter, including over 5,500 manhole structures and over 9,000 drainage structures.

The Utilities Department also coordinates with ComEd, Nicor, AT&T, and other private utilities on behalf of Evanston residents and businesses to help resolve service issues and improvement needs.

The Department's FY 2013 budget was approximately \$40.5 million (\$21.2 million Water Fund and \$19.3 million Sewer Fund). Utilities Department staff includes 55.5 full-time equivalents (FTEs).

Year-to-Year Utility Department Comparables

| | 2010 | 2011 | 2012 | 2013 |
|---|---------|---------|---------|---------|
| Total Water Pumped (millions of gallons) | 14,202 | 13,870 | 14,547 | 13,793 |
| Fire Hydrants Repaired or Replaced | 144 | 217 | 321 | 197 |
| Fire Hydrants Repainted | 0 | 0 | 284 | 325 |
| Water Main Valves Repaired or Replaced | 92 | 59 | 64 | 85 |
| Water Main Installed (miles) | 1.5 | 1.4 | 1.8 | 1.8 |
| Large Diameter Sewer Rehabilitated (feet) | 0 | 0 | 0 | 8,249 |
| Small Diameter Sewer Rehabilitated (feet) | 2,081 | 5,595 | 8,321 | 7,829 |
| Sewer Mains Inspected (feet of pipe) | 104,460 | 106,856 | 103,678 | 101,424 |
| Sewer Mains Cleaned (feet of pipe) | 275,781 | 264,738 | 248,311 | 187,966 |
| Sewer Structures Repaired or Replaced | 136 | 108 | 123 | 92 |

2013 Major Accomplishments

Major Water Treatment Facility Improvements

Replacement of the water plant supervisory, control, and data acquisition (SCADA) system moved ahead and was nearly complete by the end of 2013. The new SCADA system automates many facets of the water plant's process control system and provides many more options for capturing and tracking operational data to optimize plant performance. Filtration Division staff also installed new transmitters to measure flow rate and head loss through the filters, which will communicate with the new SCADA system to improve filter operation and efficiency.

Meter and Billing Improvements

The Utilities Department began a two-year project to upgrade the City's Automatic Meter Information (AMI) system. This is an electronic, remotely controlled system to read water meters and transmit the data to the Utilities Department for billing. As part of this upgrade project, all of the City's 14,400 water accounts will receive a new MIU (Meter Interface Unit), which is the equipment that transmits meter reading data to the AMI computer system. This project also includes replacement of approximately 10% of individual customer water meters due to their age, which should significantly improve metering and billing efficiency throughout the City.

Rehabilitation of Large Diameter Sewers

Contractors rehabilitated over 8,200 feet of large diameter sewers, ranging in size from 36-inch to 72-inch diameter. These pipelines are over 100 years old and are critical components of the combined sewer system. They were rehabilitated using the cured-in-place pipe (CIPP) lining process, to minimize surface disruption and complete the improvements as quickly and cost-effectively as possible.

Water Supply Expansion

Evanston completed a cost of service study to determine appropriate rates to supply potential new wholesale water customers. The City met with several communities and agencies throughout the year to communicate the proposed wholesale rates and outline anticipated savings for these communities as compared to continuing to receive water from Chicago.

Low Interest Loan Funding

The Utilities Department obtained a \$1,388,290 low interest (2.295%) loan through the Illinois Environmental Protection Agency's State Revolving Fund to rehabilitate 5,365 feet of 100 year-old, large diameter brick sewer mains in 2014.

Safety Improvements

The Utilities Department completed a study of the electrical system within the water treatment facility. This study included a hazard risk assessment, labeling of equipment, recommendations to reduce arc flash hazards, and testing and maintenance of the main switchgear.

2014 Major Goals and Initiatives

Major Water Treatment Facility Improvements

Install a heating system on the 48" diameter lake water intake, which will prevent anchor ice accumulation in the winter. Anchor ice can completely block a water plant intake, and nearly led to full shutdown of Evanston's water plant in 2009. This project, along with a similar project completed for the 54" diameter intake in 2010, will ensure reliability of our water supply.

Meter and Billing Improvements

Ensure the reliability of the water meter reading system and water billing system by completing the Automated Meter Information (AMI) project. Additionally, a new feature of the billing software will be implemented allowing customers to review their water usage and billing history online.

Enhance the accuracy of finished water metering by replacing the 65-year-old Venturi meter on the primary feeder main to Evanston and Skokie with a more accurate mag meter. Combined with improvements on the customer metering side, this project should significantly improve water use accounting and aid in water loss reduction efforts.

Rehabilitation of Large Diameter Sewers

Rehabilitate 5,365 feet of large diameter sewers, ranging in size from 36-inch to 72-inch diameter, using the cured-in-place pipe (CIPP) lining process. This work is part of a multi-year project to renew aging trunk sewers throughout Evanston.

Water Supply Expansion

Continue meeting with potential wholesale water customers, and partner with Morton Grove, Niles, Park Ridge, and Glenview to jointly fund an updated water supply transmission main study. The report will develop an opinion of probable construction cost, define potential transmission main routes for this new potential set of wholesale customers, establish water demands, determine appropriate pipe diameters, and develop an allocation of costs among the partner communities and agencies.

Loans and Grants

Finalize and submit loan application documents for the 48-inch diameter intake rehabilitation project (\$1.9 million) and for large diameter sewer rehabilitation (\$1.9 million). Submit preliminary loan application documents for projects proposed in 2014, including water plant reliability improvements, replacement of the finished water reservoir, replacement of the 30-inch diameter water feeder main to downtown Evanston, and additional large diameter sewer rehabilitation.

Safety Improvements

Create an electrical safety operations and training program for all staff at the water treatment plant.

Treated Water Storage Study

Complete a long-term master plan for maintaining and replacing aging treated water storage tanks at the water treatment plant.

Water Treatment Plant Data

Intakes

36/42" – 5,946' long, 28' deep

48" – 5,300' long, 28' deep

54" – 5,340' long, 28' deep

Suction Wells

2 – 22' diameter x 74' deep with traveling screens

1 – 20' diameter x 52.5' deep

Low Lift Pumps

2 – 30 mgd, electric motor driven

3 – 15 mgd, dual drive, electric/natural gas

1 – 30 mgd, dual drive, electric/natural gas

Total capacity of 135 mgd

Emergency standby capacity of 75 mgd

Flash Mix Basin

14.75' x 14.75' x 31.58' deep

Single vertical shaft mixer

Counter-flow rotation

Application point for alum, chlorine, fluoride, polymer, and carbon

Rated capacity 108 mgd w/ partial bypass

Slow Mix/Settling Basins

Four double-deck basins with series flow

2 – 2.865 MG capacity, five 60' shafts per basin, 4 paddle wheel sections

2 – 4.3 MG capacity, eight 60' shafts per basin, 4 paddle wheel sections

Retention time at 108 mgd (flash mix capacity) is 3 hours and 11 minutes

Standpipes

South – 5.0 MG, 640 Hartrey Avenue

North – 7.5 MG, 2536 Gross Point Road

Legend: MG = million gallons; mgd = million gallons per day; gpm = gallons per minute

Filters

Anthracite-capped rapid sand filters

12 – 3.19 mgd, 738 ft² each, surface loading rate of 3 gpm/ft^s

12 – 8.01 mgd, 1,391 ft² each, surface loading rate of 4 gpm/ft²

Total rated capacity of 134 mgd

Automatic surface and backwash system on all 24 filters

Underground Storage

8 clearwells beneath filters – 4.4 MG total

1 clearwell beneath NU parking lot – 5.0 MG

Total Plant Storage – 9.4 MG

High Lift Pumps

1 – 15 mgd, electric motor driven

2 – 25 mgd, electric motor driven

1 – 10 mgd, dual drive, electric/natural gas

2 – 15 mgd, dual drive, electric/natural gas

1 – 22 mgd, dual drive, electric/natural gas

1 – 20 mgd, natural gas engine

Total capacity of 147 mgd

Emergency standby capacity of 82 mgd

Wash Water Pumps

2 – 20 mgd

2 – 10 mgd


Detention Tank

80' x 192' x 12' deep, divided in 2 sections

Total capacity of 1.1 MG

1 – submersible sludge pump at 700 gpm

Water Treatment Schematic



The Evanston Water Treatment Plant provides conventional treatment (mixing, flocculation, sedimentation, and filtration). Filtered water gravitates to 8 clearwells with a total volume of 4.4 MG and a separate 5.0 MG clearwell. Total filtration capacity is 134 mgd. Firm filtration capacity (one filter out of service) is 126 mgd. Rated capacity of the plant is limited by the size of process piping to 108 mgd.

| | | | | | |
|-------------|-------|-------|--------|-------|--------|
| Volume (MG) | 0.109 | 2.384 | 13.516 | 1.730 | 9.560* |
|-------------|-------|-------|--------|-------|--------|

Notes:
*based on 8.0' depth

Water Works Improvements (1874 to 2013)

- 1874** Evanston Community Water System established
- 1913** Constructed 12 mgd filter plant
- 1923** Expanded filter plant to 24 mgd
- 1934** Constructed 5.0 million gallon underground reservoir at plant site
- 1944** Contracted to supply water to Skokie
- 1949** Constructed high lift (finished water) pumping station
Expanded filter plant to 48 mgd
Constructed slow mix basins 1 and 2
- 1956** Constructed 48" intake and low lift (raw water) pump station
Constructed 36" feeder main to Skokie
- 1964** Expanded filter plant to 72 mgd
Constructed additional 36" feeder main to Skokie
Constructed slow mix basins 3 and 4
- 1971** Installed 20 mgd high lift pump and natural gas engine
- 1974** Constructed filter wash water detention basin, 1.1 MG capacity
- 1976** Constructed 54" intake, 5,340 feet in length
Extended 48" intake to 5,300 feet in length
- 1981** Constructed material storage building at south water tank yard
Installed 3 new boilers (2 – 50 HP and 1 – 20 HP)
Replaced 5 kV switchgear and motor starter equipment for low lift pumps
Upgraded slow mix equipment in basins 1 and 2
- 1982** Installed two 30 mgd low lift pumps
Replaced 5 kV motor starter center for high lift pumps
- 1983** Constructed new chemical building and chemical feed system
Installed a 500 kW emergency generator
Rehabilitated six 1914 and six 1924 filters to increase rate to 3 MGD per filter
- 1984** Constructed 5 MG standpipe with booster station to replace the 1.5 MG elevated tank in southwest Evanston

- 1985** Began selling water to Northwest Water Commission at the rate of 10 MGD
Installed dual drive 22 MGD high lift pump and new piping
Installed two 48" diameter pipes from reservoir to east side of high lift suction tunnel
Completed system automation which provided a microprocessor-based digital control system to perform control and supervisory functions
- 1986** Constructed a 7.5 MG standpipe with booster station to replace the 1.0 MG elevated tank in northwest Evanston
Began pumping to Northwest Water Commission reservoir in Des Plaines
- 1988** Installed two 700 gpm sludge pumps with automatic samplers in the settling basins along with 3,400 feet of 8" diameter sludge main from the Filtration Plant to the MWRD interceptor at Lincoln Street and Asbury Ave
- 1989** Completed filter control upgrade to microprocessors
- 1990** Turndown and extension of 48" raw water intake lines into North and South suction wells
Upgraded west filter influent valves from 16" to 24"
- 1991** Upgraded electrical substation and switchgear to 3,750 kVA
Upgraded west filter effluent piping
- 1992** Installed chlorine feed system to intakes for zebra/quagga mussel control
Installed a 15 MGD high lift pump to replace one 8 MGD pump and one 6 MGD pump
Installed two 48" diameter butterfly valves on suction piping from reservoir to high lift suction wells
Installed hydrofluosilicic acid tank and feed system in garage #6
Installed 60" diameter flash mix bypass pipe to influent duct of settling basins
Replaced slow mix equipment and flushing system in basins 3 and 4
Replaced 480 V filter plant switchgear
Installed blended phosphate system and initiated blended phosphate treatment for corrosion control
- 1994** Constructed new chemical storage and handling building
- 1995** Replaced Low Lift Pump #6 gasoline engine with natural gas engine
- 1996** Replaced 1949 filter building roof
Constructed loading dock on 1913 filter building
- 1997** Replaced High Lift Pump #2 gasoline with a natural gas engine
- 1998** Replaced Low Lift Pump #5 and #7 dual drive gasoline engines with natural gas fueled engines


- 2000** Installed individual effluent turbidimeters on all 24 filters
- 2001** Converted High Lift Pump #3 to dual drive
Replaced filter bottoms and rehabbed six filters in 1948 filter addition
- 2002** Completed installation of automatic fixed radio meter reading system
Replaced effluent settling basin sluice gates with rectangular butterfly valves
- 2003** Installed uninterruptible power supply to filtration and pumping equipment
- 2004** Constructed garages east of the settling basins
Constructed an access way to the chemical building from filtration division
Installed a scrubber
- 2005** Replaced Low Lift Pump #4 gasoline engine with natural gas engine
- 2006** Replaced Low Lift Pump #7
- 2008** Renovated administrative offices
Expanded filter shop area
- 2009** Implemented AQUAS (Harris) Utility Billing System
Installed anchor ice and zebra mussel control systems in 54" intake
- 2010** Installed a 25 kW solar energy facility on the high lift pump station roof
- 2012** Rehabilitated Filters 19-24 with new media, underdrains, and backwash equipment
Rehabilitated the 1963 filter building structure and roof
Replaced all windows in the high lift pump station
Replaced electrical switchgear in high lift pump station
- 2013** Modified electrical distribution equipment and settings on protective devices throughout the water treatment plant to reduce arc flash hazards
Conducted comprehensive maintenance and evaluation of electrical switchgears

Notes: MG = million gallons
mgd = million gallons per day
HP = horsepower
kV = kilovolt
kW = kilowatt
kVA = kilovolt-ampere

Service Area & Population


| | Area (Square Miles) | 2013 Persons* |
|-----------------------------------|------------------------|------------------|
| Evanston | 7.8 | 75,570 |
| Skokie | 10.5 | 65,176 |
| NORTHWEST WATER COMMISSION | | |
| Arlington Heights | 15 | 75,994 |
| Buffalo Grove | 4.5 | 41,778 |
| Palatine | 9 | 69,350 |
| Wheeling | 7.5 | 38,015 |
| Total Served | 54.3 | 365,883 |

* U.S. Census Bureau, 2013 Estimate




Pumpage to Distribution

2013 Pumpage to Distribution (MG)



2013 Total Pumpage: 13,792,785,000 gallons


2012 Pumpage to Distribution (MG)



2012 Total Pumpage: 14,546,581,000 gallons

Water Revenues*

| | 2012 | 2013 |
|----------------------------|---------------------|---------------------|
| Evanston Water Sales | \$6,248,329 | \$5,947,633 |
| Skokie Water Sales | \$2,989,109 | \$2,772,424 |
| NWC Water Sales | \$5,033,996 | \$5,183,425 |
| Debt Proceeds | \$4,400,000 | \$2,000,000 |
| Miscellaneous Revenue** | \$700,787 | \$766,522 |
| Total Water Revenue | \$19,372,222 | \$16,670,004 |




* Financial data are based on actual expenses and do not include audit adjustments such as depreciation and inventory. For audited financial records, see the Comprehensive Annual Financial Report for the City of Evanston, <http://www.cityofevanston.org/transparency/budget-financial-reports/>.

** Miscellaneous Revenue includes cross connection control fees, investment earnings, property sales and rentals, fees, grants, insurance reimbursements, development fees, phosphate sales, and merchandise sales.

Water Operating & Maintenance Expenses*

| | 2012 | 2013 |
|----------------------------|---------------------|---------------------|
| General Support | \$832,831 | \$941,682 |
| Pumping | \$2,364,465 | \$2,322,648 |
| Filtration | \$2,902,021 | \$2,460,495 |
| Distribution | \$1,441,374 | \$1,423,105 |
| Meter Maintenance | \$313,841 | \$259,201 |
| Other Operating Expenses** | \$4,171,622 | \$4,546,816 |
| Total | \$12,028,166 | \$11,955,960 |



* Financial data are based on actual expenses and do not include audit adjustments such as depreciation and inventory. For audited financial records, see the Comprehensive Annual Financial Report for the City of Evanston, <http://www.cityofevanston.org/transparency/budget-financial-reports/>.

**Other Operating Expenses include capital outlay, interfund transfers, and other operating expenses.

Employee Profile and Safety


| Section | Employee Full-Time Equivalents |
|----------------|---------------------------------------|
| Administration | 5.0 |
| Pumping | 11.0 |
| Filtration | 14.0 |
| Distribution* | 10.5 |
| Sewer | 13.0 |
| Meter | 2.0 |
| Total | 55.5 |

| Section | Number of AFMD** Beginning of Year | Number of Accidents | Highest consecutive AFMD achieved | Date Highest AFMD Achieved | Number of AFMD End of Year |
|----------------------|---|----------------------------|--|-----------------------------------|-----------------------------------|
| Pumping | 227.5 | 1 | 2,456.0 | 9/10/2013 | 394.0 |
| Filtration | 2,176.0 | 1 | 3,268.0 | 3/7/2013 | 2,071.5 |
| Distribution & Sewer | 3,025.5 | 1 | 3,785.5 | 1/27/2013 | 2,644.5 |

* Includes one Civil Engineer working in the Public Works Department.

** AFMD = Accident Free Man Days

Pumping



The original Water Works was built in 1874 to provide water for Evanston's 3,500 residents. The system consisted of a 16-inch intake pipe extending 1,200 feet into the lake, a small Holly steam engine capable of pumping 2 million gallons per day, a hand fired boiler, and a few miles of cast iron water main. The original cost of the steam engine and boiler was \$24,000. During the first year of operation the plant pumped 95 million gallons of water.

2013 Monthly Pumpage (MG)

| Month | Lake Water Pumpage | Wash Water Recycled | Net Raw Water Pumpage | Finished Water Pumpage | Pumpage To | | | |
|---------------------|--------------------|---------------------|-----------------------|------------------------|-------------------|------------------|------------------|------------------|
| | | | | | Distribution | Evanston | Skokie | N.W.C. |
| Jan-13 | 1,107.455 | 23.542 | 1,130.997 | 1,099.643 | 1,094.500 | 242.958 | 227.784 | 623.758 |
| Feb-13 | 1,028.019 | 16.835 | 1,044.854 | 1,017.931 | 1,014.861 | 176.603 | 207.447 | 630.811 |
| Mar-13 | 1,066.409 | 19.530 | 1,085.939 | 1,064.242 | 1,059.277 | 223.635 | 211.516 | 624.126 |
| Apr-13 | 1,052.096 | 19.348 | 1,071.444 | 1,044.845 | 1,039.738 | 235.181 | 190.216 | 614.341 |
| May-13 | 1,230.328 | 20.994 | 1,251.322 | 1,209.006 | 1,209.420 | 275.072 | 214.328 | 720.020 |
| Jun-13 | 1,193.089 | 18.085 | 1,211.174 | 1,178.601 | 1,178.034 | 258.697 | 229.677 | 689.660 |
| Jul-13 | 1,337.949 | 24.511 | 1,362.460 | 1,326.909 | 1,327.293 | 279.050 | 259.219 | 789.024 |
| Aug-13 | 1,417.370 | 29.043 | 1,446.413 | 1,414.055 | 1,411.911 | 286.767 | 297.072 | 828.072 |
| Sep-13 | 1,257.341 | 22.479 | 1,279.820 | 1,252.816 | 1,251.606 | 249.875 | 268.462 | 733.269 |
| Oct-13 | 1,127.452 | 19.927 | 1,147.379 | 1,102.623 | 1,101.016 | 209.147 | 236.286 | 655.583 |
| Nov-13 | 1,020.070 | 16.411 | 1,036.481 | 1,015.941 | 1,016.663 | 224.487 | 213.690 | 578.486 |
| Dec-13 | 1,087.524 | 16.904 | 1,104.428 | 1,087.849 | 1,088.466 | 247.130 | 231.559 | 609.777 |
| Annual Total | 13,925.102 | 247.609 | 14,172.711 | 13,814.461 | 13,792.785 | 2,908.602 | 2,787.256 | 8,096.927 |


2013 Average Day Pumpage (MGD)

| Month | Lake Water Pumpage* | Wash Water Recycled | Net Raw Water Pumpage | Finished Water Pumpage | Pumpage To | | | |
|-----------------------|---------------------|---------------------|-----------------------|------------------------|---------------|--------------|--------------|---------------|
| | | | | | Distribution | Evanston | Skokie | N.W.C. |
| Jan-13 | 35.724 | 0.759 | 36.484 | 35.472 | 35.306 | 7.837 | 7.348 | 20.121 |
| Feb-13 | 36.715 | 0.601 | 37.316 | 36.355 | 36.245 | 6.307 | 7.409 | 22.529 |
| Mar-13 | 34.400 | 0.630 | 35.030 | 34.330 | 34.170 | 7.214 | 6.823 | 20.133 |
| Apr-13 | 33.939 | 0.645 | 35.715 | 34.828 | 34.658 | 7.839 | 6.341 | 20.478 |
| May-13 | 39.688 | 0.624 | 34.563 | 39.000 | 39.014 | 8.873 | 6.914 | 23.226 |
| Jun-13 | 39.770 | 0.603 | 40.372 | 39.287 | 39.268 | 8.623 | 7.656 | 22.989 |
| Jul-13 | 43.160 | 0.791 | 43.950 | 42.804 | 42.816 | 9.002 | 8.362 | 25.452 |
| Aug-13 | 45.722 | 0.937 | 46.658 | 45.615 | 45.546 | 9.251 | 9.583 | 26.712 |
| Sep-13 | 41.911 | 0.749 | 42.661 | 41.761 | 41.720 | 8.329 | 8.949 | 24.442 |
| Oct-13 | 36.369 | 0.643 | 37.012 | 35.568 | 35.517 | 6.747 | 7.622 | 21.148 |
| Nov-13 | 34.002 | 0.547 | 34.549 | 33.865 | 33.889 | 7.483 | 7.123 | 19.283 |
| Dec-13 | 35.081 | 0.545 | 35.627 | 35.092 | 35.112 | 7.972 | 7.470 | 19.670 |
| Annual Average | 38.151 | 0.678 | 38.829 | 37.848 | 37.788 | 7.969 | 7.636 | 22.183 |

Note: The sum of metered pumpage to Evanston, Skokie, and NWC (totaled under Pumpage to Distribution) sometimes exceeds the master Finished Water Pumpage figure due to minor metering inaccuracies.

Annual Pumpage (MG)

| Year | Lake Water Pumpage | Wash Water Recycled | Total Raw Water Pumpage | Finished Water Pumpage | Pumpage To | | | |
|------|--------------------|---------------------|-------------------------|------------------------|--------------|-----------|-----------|-----------|
| | | | | | Distribution | Evanston | Skokie | N.W.C. |
| 2013 | 13,925.102 | 247.609 | 14,172.711 | 13,814.461 | 13,792.785 | 2,908.602 | 2,787.256 | 8,096.927 |
| 2012 | 14,817.637 | 322.302 | 15,110.465 | 14,627.115 | 14,546.676 | 2,858.883 | 3,068.004 | 8,619.694 |
| 2011 | 13,939.618 | 212.426 | 14,152.042 | 13,941.167 | 13,869.954 | 2,920.633 | 2,866.652 | 8,082.667 |
| 2010 | 14,087.849 | 218.251 | 14,306.100 | 14,268.257 | 14,202.176 | 2,635.488 | 3,094.554 | 8,472.134 |
| 2009 | 14,363.047 | 193.841 | 14,556.888 | 14,350.335 | 14,199.531 | 2,990.094 | 2,829.824 | 8,379.613 |
| 2008 | 14,872.552 | 134.595 | 15,007.147 | 14,693.877 | 14,626.296 | 3,089.536 | 2,961.341 | 8,589.720 |
| 2007 | 15,905.381 | 192.088 | 16,097.469 | 15,771.451 | 15,704.746 | 3,140.717 | 3,564.781 | 8,999.248 |
| 2006 | 15,332.651 | 160.528 | 15,493.179 | 15,174.631 | 15,115.821 | 2,891.989 | 3,329.305 | 8,894.627 |
| 2005 | 16,823.362 | 184.937 | 17,008.299 | 16,634.025 | 16,572.712 | 3,303.763 | 3,544.779 | 9,724.170 |
| 2004 | 15,760.615 | 126.348 | 15,886.963 | 15,550.728 | 15,493.940 | 3,200.427 | 3,365.418 | 8,928.095 |



Average Daily per Capita Consumption




| Year | Evanston | | Skokie | | NWC | | Total | |
|------|------------|-----------------------|------------|-----------------------|------------|-----------------------|------------|-----------------------|
| | Population | Per Capita Use (gpcd) | Population | Per Capita Use (gpcd) | Population | Per Capita Use (gpcd) | Population | Per Capita Use (gpcd) |
| 2013 | 74,486 | 107 | 64,784 | 118 | 222,802 | 100 | 362,072 | 104 |
| 2012 | 74,486 | 105 | 64,784 | 130 | 222,802 | 106 | 362,072 | 110 |
| 2011 | 74,486 | 107 | 64,784 | 121 | 222,802 | 99 | 362,072 | 105 |
| 2010 | 74,486 | 97 | 64,784 | 131 | 222,802 | 104 | 362,072 | 107 |
| 2009 | 74,360 | 110 | 63,333 | 122 | 221,364 | 104 | 359,057 | 108 |
| 2008 | 74,360 | 114 | 63,333 | 128 | 221,364 | 106 | 359,057 | 112 |
| 2007 | 74,360 | 116 | 63,333 | 154 | 221,364 | 111 | 359,057 | 120 |
| 2006 | 74,360 | 107 | 63,633 | 143 | 221,364 | 110 | 359,357 | 115 |
| 2005 | 74,360 | 122 | 63,633 | 153 | 221,364 | 120 | 359,357 | 126 |
| 2004 | 74,360 | 118 | 63,633 | 145 | 221,364 | 110 | 359,357 | 118 |

Maximum Pumpage to Distribution

| Year | Max Day Pumpage Volume (MG) | Peak Hour Pumpage Rate (MGD) | Peak Hour Pumpage Volume (MG) |
|------|-----------------------------|------------------------------|-------------------------------|
| 2013 | 56.946 | 72.072 | 3.003 |
| 2012 | 69.210 | 85.680 | 3.570 |
| 2011 | 66.096 | 75.144 | 3.131 |
| 2010 | 57.020 | 89.520 | 3.730 |
| 2009 | 58.940 | 67.440 | 2.810 |
| 2008 | 57.478 | 69.480 | 2.895 |
| 2007 | 65.997 | 70.632 | 2.943 |
| 2006 | 65.961 | 70.248 | 2.927 |
| 2005 | 80.381 | 88.848 | 3.702 |
| 2004 | 60.395 | 69.264 | 2.886 |

Historical Maximum Day Pumpage: 95.154 MG on July 7, 1989

Maximum Day and Peak Hour Pumpage



Maximum Pumpage Days (MGD)

| Year | Maximum Day Pumpage To | | | |
|------|------------------------|-------------|-------------|-------------|
| | Distribution | Evanston | Skokie | NWC |
| 2013 | August 28th | August 28th | August 28th | August 27th |
| | 72.072 | 12.585 | 11.209 | 33.374 |
| 2012 | July 17th | July 17th | July 17th | July 6th |
| | 69.210 | 18.580 | 13.579 | 43.775 |
| 2011 | July 18th | July 18th | July 18th | July 19th |
| | 66.096 | 12.614 | 13.724 | 40.820 |
| 2010 | July 17th | July 29th | August 20th | July 19th |
| | 57.020 | 13.643 | 12.957 | 34.661 |
| 2009 | August 14th | August 13th | August 14th | August 6th |
| | 58.940 | 13.992 | 11.495 | 34.725 |
| 2008 | July 30th | July 30th | July 30th | July 29th |
| | 57.478 | 11.788 | 11.495 | 33.670 |
| 2007 | August 2nd | August 2nd | June 11th | August 2nd |
| | 65.997 | 17.774 | 16.493 | 35.946 |
| 2006 | August 1st | July 29th | August 1st | August 1st |
| | 65.961 | 14.127 | 15.236 | 37.221 |
| 2005 | June 24th | July 17th | June 24th | June 24th |
| | 80.381 | 16.926 | 17.268 | 47.233 |
| 2004 | August 2nd | August 3rd | July 2nd | July 30th |
| | 60.395 | 14.497 | 11.895 | 35.471 |

Historical Maximum Day Pumpage to Distribution: 95.154 MG on July 7, 1989

Energy Costs

Electric Power - Kilowatt Hours (kWh) Used

| Year | Total kWh | Total Cost* | Average Cost \$/kWh |
|------|------------|-------------|---------------------|
| 2013 | 11,529,489 | \$779,226 | \$0.068 |
| 2012 | 13,706,324 | \$924,422 | \$0.067 |
| 2011 | 13,462,281 | \$841,245 | \$0.062 |
| 2010 | 12,009,162 | \$821,166 | \$0.068 |
| 2009 | 11,290,287 | \$829,181 | \$0.073 |

* 2012 cost is higher than usual due to increased pumpage during a drought.

Natural Gas Used for Pumping and Emergency Engines*

| Year | Therms | Total Cost** | Average Cost \$/Therm |
|------|---------|--------------|-----------------------|
| 2013 | 129,481 | \$86,926 | \$0.671 |
| 2012 | 124,954 | \$83,901 | \$0.671 |
| 2011 | 225,100 | \$116,272 | \$0.517 |
| 2010 | 51,552 | \$32,237 | \$0.625 |
| 2009 | 37,203 | \$28,274 | \$0.760 |

* Includes natural gas purchase and delivery charges.

** 2011 cost is elevated due to switchgear fire, which required extended emergency generator use.



Total Energy Cost (Electric & Gas)

| Year | Total |
|------|-------------|
| 2013 | \$866,152 |
| 2012 | \$1,008,323 |
| 2011 | \$957,517 |
| 2010 | \$899,264 |
| 2009 | \$857,455 |

Total Energy Cost Per Million Gallons of Finished Water Pumped


| | |
|------|---------|
| 2013 | \$62.80 |
| 2012 | \$69.32 |
| 2011 | \$69.04 |
| 2010 | \$63.32 |
| 2009 | \$60.38 |

Energy Costs



* Energy costs increased in 2012 due to increased pumping during the summer drought.

Filtration



The original plant received an addition in 1888, allowing the installation of a second Holly engine. This was originally intended to replace the first engine, but growing demand kept both engines running. In 1892, the village of South Evanston was annexed, becoming a water user.


Chemical Treatment: Chemicals Used and Costs

| | Chemical Feed (lbs/MG) | | | Unit Cost | Pounds per Year | Total Cost | Cost per MG Treated |
|---------------------------------------|------------------------|---------|---------|--------------------|-----------------|------------|---------------------|
| | Avg Daily | Max Day | Min Day | | | | |
| Aluminum Sulfate | | | | | | | |
| 2013 | 54.8 | 97.2 | 39.5 | \$447.28 / dry ton | 770,838 | \$172,390 | \$12.16 |
| 2012 | 55.9 | 101.6 | 30.2 | \$447.28 / dry ton | 830,624 | \$185,761 | \$12.27 |
| 2011 | 63.0 | 103.8 | 39.6 | \$413.87 / dry ton | 870,836 | \$181,138 | \$12.80 |
| 2010 | 59.0 | 103.8 | 39.3 | \$400.10 / dry ton | 830,688 | \$166,179 | \$11.62 |
| 2009 | 53.6 | 100.5 | 31.7 | \$440.00 / dry ton | 607,724 | \$124,161 | \$12.09 |
| Alumer* | | | | | | | |
| 2009 | 35.5 | 76.5 | 24.3 | \$420.00/ dry ton | 146,180 | \$66,116 | \$15.93 |
| 2004 | 30.1 | 55.6 | 18.1 | \$122.00/ dry ton | 476,768 | \$66,582 | \$4.19 |
| Chlorine | | | | | | | |
| 2013 | 12.2 | 17.9 | 7.6 | \$365.00 / ton | 176,190 | \$32,155 | \$2.27 |
| 2012 | 12.0 | 20.0 | 7.0 | \$424.50 / ton | 187,315 | \$39,758 | \$2.63 |
| 2011 | 12.7 | 18.8 | 8.4 | \$367.50 / ton | 180,870 | \$33,235 | \$2.35 |
| 2010 | 12.3 | 16.2 | 8.8 | \$367.50 / ton | 176,125 | \$32,363 | \$2.26 |
| 2009 | 11.9 | 17.6 | 7.3 | \$367.00 / ton | 172,880 | \$31,767 | \$2.20 |
| Activated Carbon** | | | | | | | |
| Hydrofluosilic Acid (Fluoride) | | | | | | | |
| 2013 | 37.7 | 61.1 | 29.3 | \$539.00 / ton | 534,550 | \$144,061 | \$10.16 |
| 2012 | 36.2 | 38.2 | 33.3 | \$596.00 / ton | 547,011 | \$163,009 | \$10.77 |
| 2011 | 38.4 | 53.0 | 26.5 | \$685.00 / ton | 542,886 | \$185,938 | \$13.14 |
| 2010 | 40.1 | 42.8 | 37.8 | \$685.00 / ton | 574,004 | \$196,597 | \$13.75 |
| 2009 | 39.4 | 43.0 | 23.1 | \$635.00 / ton | 568,907 | \$180,628 | \$12.51 |
| Polymer | | | | | | | |
| 2013 | 3.3 | 6.1 | 2.3 | \$760.00 / ton | 46,584 | \$17,702 | \$1.25 |
| 2012 | 3.4 | 6.1 | 2.0 | \$870.00 / ton | 51,318 | \$22,323 | \$1.47 |
| 2011 | 3.9 | 6.5 | 2.3 | \$700.00 / ton | 53,499 | \$18,725 | \$1.32 |
| 2010 | 3.6 | 6.2 | 2.3 | \$700.00 / ton | 50,316 | \$17,611 | \$1.23 |
| 2009 | 3.7 | 6.2 | 2.0 | \$660.00 / ton | 52,801 | \$17,424 | \$1.21 |
| Blended Phosphate | | | | | | | |
| 2013 | 12.5 | 14.0 | 11.3 | \$4.98 / gallon | 173,141 | \$74,978 | \$5.29 |
| 2012 | 12.3 | 18.5 | 11.0 | \$5.15 / gallon | 181,034 | \$81,072 | \$5.35 |
| 2011 | 14.7 | 19.1 | 10.7 | \$4.83 / gallon | 203,601 | \$85,512 | \$6.04 |
| 2010 | 12.5 | 18.4 | 10.7 | \$4.83 / gallon | 176,954 | \$74,321 | \$5.20 |
| 2009 | 12.7 | 14.9 | 10.9 | \$6.71 / gallon | 181,070 | \$105,650 | \$7.32 |

* Alumer is a mixture of aluminum sulfate and polymer that was tested in 2004, and used from 5/27/09 to 8/29/09.

** Carbon can be fed for taste and odor control, though this has not been necessary since 2005.

Annual Chemical Costs



Filter Operations

Filter Runs

| Year | Avg Hours per Filter Run | | Total Hours per Year | |
|------|--------------------------|-------|----------------------|---------|
| | 3 MGD | 8 MGD | 3 MGD | 8 MGD |
| 2013 | 224.5 | 200.6 | 95,958 | 101,536 |
| 2012 | 208.7 | 171.5 | 96,000 | 92,402 |
| 2011 | 229.1 | 197.3 | 96,336 | 88,162 |
| 2010 | 229.2 | 198.8 | 96,286 | 100,046 |
| 2009 | 253.8 | 239.2 | 97,313 | 94,790 |
| 2008 | 266.7 | 228.5 | 97,050 | 100,601 |
| 2007 | 234.9 | 200.7 | 91,395 | 104,530 |
| 2006 | 245.4 | 226.9 | 105,043 | 105,059 |
| 2005 | 224.7 | 201.7 | 104,595 | 105,031 |
| 2004 | 266.7 | 249.5 | 105,965 | 105,110 |

Filter Washes

| Year | Total Washes per Year | | Max # of Washes per Day | |
|------|-----------------------|-------|-------------------------|-------|
| | 3 MGD | 8 MGD | 3 MGD | 8 MGD |
| 2013 | 427 | 524 | 7 | 7 |
| 2012 | 476 | 611 | 7 | 9 |
| 2011 | 430 | 486 | 5 | 6 |
| 2010 | 452 | 559 | 7 | 7 |
| 2009 | 387 | 409 | 6 | 5 |
| 2008 | 369 | 460 | 6 | 6 |
| 2007 | 425 | 569 | 6 | 7 |
| 2006 | 453 | 503 | 5 | 6 |
| 2005 | 522 | 614 | 6 | 8 |
| 2004 | 404 | 419 | 6 | 7 |

Wash Water

| Year | Total (MG) | Avg Daily % | Max Daily % |
|------|------------|-------------|-------------|
| 2013 | 248.996 | 1.78 | 6.20 |
| 2012 | 321.030 | 2.13 | 9.72 |
| 2011 | 211.546 | 1.49 | 5.14 |
| 2010 | 223.704 | 1.53 | 15.20 |
| 2009 | 149.063 | 1.02 | 4.54 |
| 2008 | 145.593 | 0.95 | 4.15 |
| 2007 | 192.135 | 1.15 | 4.86 |
| 2006 | 160.264 | 1.01 | 3.25 |
| 2005 | 184.088 | 1.03 | 3.45 |
| 2004 | 127.261 | 0.79 | 4.22 |

Bacteriological Water Analysis (Membrane Filter Method)

Report of Evanston Water Quality Control Laboratory

The U.S. Environmental Protection Agency (EPA) standard is based on the presence or absence of total coliform bacteria in a water sample. The EPA requires that no more than 5% of monthly samples from the City's water distribution system test positive for the presence of total coliform. Evanston is required to collect 80 water samples per month from the distribution system.

| Distribution System | | Positive for | Positive for |
|---------------------|----------------|----------------|----------------|
| Year | Number Sampled | Total Coliform | Fecal Coliform |
| 2013 | 981 | 1 | 0 |
| 2012 | 995 | 2 | 0 |
| 2011 | 993 | 4 | 0 |
| 2010 | 994 | 4 | 1 |
| 2009 | 965 | 2 | 0 |

Additional Bacteriological Samples Analyzed for the Village of Skokie

| Year | Number Sampled |
|------|----------------|
| 2013 | 899 |
| 2012 | 914 |
| 2011 | 900 |
| 2010 | 941 |
| 2009 | 918 |

| Raw Water | Year | Number Sampled | Colony Count | |
|-----------|------|-------------------|--------------|---------|
| | | | Average | Maximum |
| | 2013 | 730 (Twice Daily) | 45 | >200 |
| | 2012 | 732 (Twice Daily) | 41 | >200 |
| | 2011 | 730 (Twice Daily) | 102 | >200 |
| | 2010 | 730 (Twice Daily) | 96 | >200 |
| | 2009 | 730 (Twice Daily) | 59 | >200 |

| After Primary Treatment | Year | Number Sampled | Colony Count | |
|-------------------------|------|-------------------|--------------|---------|
| | | | Average | Maximum |
| | 2013 | 730 (Twice Daily) | 0 | 0 |
| | 2012 | 732 (Twice Daily) | 0 | 0 |
| | 2011 | 730 (Twice Daily) | 0 | 0 |
| | 2010 | 730 (Twice Daily) | 0 | 0 |
| | 2009 | 730 (Twice Daily) | 0 | 0 |

| Plant Tap A.M. and P.M. Samples | Year | Number Sampled | Colony Count | |
|---------------------------------|------|----------------------|--------------|---------|
| | | | Average | Maximum |
| | 2013 | 1460 (4 times Daily) | 0 | 0 |
| | 2012 | 1464 (4 times Daily) | 0 | 0 |
| | 2011 | 1460 (4 times Daily) | 0 | 0 |
| | 2010 | 1460 (4 times Daily) | 0 | 0 |
| | 2009 | 1460 (4 times Daily) | 0 | 0 |

Taste & Odor, Turbidity, Temperature and Fluoride Report of Water Quality Control Laboratory

Taste & Odor

| Year | Number of Tests* |
|------|------------------|
| 2013 | 508 |
| 2012 | 504 |
| 2011 | 756 |
| 2010 | 2,190 |
| 2009 | 2,190 |

Turbidity (Expressed in Nephelometric Turbidity Units or NTU)

EPA standard is <0.3 NTU in 95% of samples and never >1 NTU in any single sample of finished water.

| Year | Raw Water | | | After Primary Treatment | | | Plant Tap | | |
|------|-----------|-------|------|-------------------------|------|------|-----------|------|------|
| | Avg | Max | Min | Avg | Max | Min | Avg | Max | Min |
| 2013 | 8.49 | 85.5 | 0.49 | 0.75 | 2.35 | 0.06 | 0.08 | 0.16 | 0.07 |
| 2012 | 9.59 | 124.0 | 0.55 | 0.74 | 2.71 | 0.25 | 0.08 | 0.18 | 0.06 |
| 2011 | 19.66 | 143.0 | 0.54 | 0.98 | 4.20 | 0.06 | 0.08 | 0.40 | 0.06 |
| 2010 | 13.50 | 127.0 | 0.51 | 0.79 | 2.60 | 0.27 | 0.09 | 0.23 | 0.06 |
| 2009 | 10.07 | 100.0 | 0.42 | 0.72 | 1.81 | 0.27 | 0.08 | 0.14 | 0.05 |

Raw Water Temperature

| Year | Average | Maximum | Minimum |
|------|-----------------|-----------------|-----------------|
| 2013 | 11.2°C / 52.1°F | 24.5°C / 76.1°F | 0.08°C / 33.4°F |
| 2012 | 12.9°C / 55.3°F | 26.8°C / 80.2°F | 2.1°C / 35.8°F |
| 2011 | 11.3°C / 52.3°F | 25.0°C / 77.0°F | 0.8°C / 33.4°F |
| 2010 | 10.6°C / 51.2°F | 22.0°C / 71.6°F | 0.8°C / 33.4°F |
| 2009 | 10.3°C / 50.5°F | 22.3°C / 72.1°F | 0.8°C / 33.4°F |

Fluoride Content (ppm)

E.P.A. standard is 0.9 to 1.2 ppm.

| Year | Plant Tap | | | Distribution | | |
|------|-----------|------|------|--------------|------|------|
| | Avg | Max | Min | Avg | Max | Min |
| 2013 | 0.97 | 1.11 | 0.90 | 0.98 | 1.09 | 0.90 |
| 2012 | 0.98 | 1.09 | 0.90 | 0.98 | 1.08 | 0.90 |
| 2011 | 0.99 | 1.11 | 0.90 | 1.00 | 1.11 | 0.90 |
| 2010 | 0.98 | 1.11 | 0.90 | 0.98 | 1.09 | 0.90 |
| 2009 | 1.01 | 1.20 | 0.90 | 1.03 | 1.19 | 0.92 |

* Taste & Odor testing requirements changed in 2011 (fewer days per week and fewer samples per day)

Chlorine Residual (ppm)

Report of Water Quality Control Laboratory

Filter Influent

| Year | Free Residual | | | Total Residual | | |
|------|---------------|------|------|----------------|------|------|
| | Avg | Max | Min | Avg | Max | Min |
| 2013 | 0.64 | 0.92 | 0.35 | 0.77 | 1.06 | 0.49 |
| 2012 | 0.68 | 1.04 | 0.44 | 0.81 | 1.19 | 0.54 |
| 2011 | 0.67 | 0.96 | 0.42 | 0.81 | 1.14 | 0.49 |
| 2010 | 0.63 | 0.94 | 0.26 | 0.78 | 1.11 | 0.36 |
| 2009 | 0.59 | 0.89 | 0.28 | 0.76 | 1.13 | 0.46 |

Filter Effluent

| Year | Free Residual | | | Total Residual | | |
|------|---------------|------|------|----------------|------|------|
| | Avg | Max | Min | Avg | Max | Min |
| 2013 | 0.55 | 0.83 | 0.30 | 0.67 | 0.97 | 0.40 |
| 2012 | 0.59 | 0.92 | 0.40 | 0.71 | 1.04 | 0.51 |
| 2011 | 0.58 | 0.86 | 0.36 | 0.71 | 0.99 | 0.48 |
| 2010 | 0.55 | 0.85 | 0.23 | 0.70 | 0.96 | 0.48 |
| 2009 | 0.50 | 0.86 | 0.22 | 0.66 | 1.06 | 0.39 |

Plant Tap

| Year | Free Residual | | | Total Residual | | |
|------|---------------|------|------|----------------|------|------|
| | Avg | Max | Min | Avg | Max | Min |
| 2013 | 0.66 | 0.88 | 0.46 | 0.80 | 1.07 | 0.60 |
| 2012 | 0.67 | 1.00 | 0.48 | 0.81 | 1.15 | 0.60 |
| 2011 | 0.67 | 0.94 | 0.49 | 0.81 | 1.17 | 0.62 |
| 2010 | 0.66 | 0.83 | 0.48 | 0.82 | 1.05 | 0.62 |
| 2009 | 0.65 | 0.89 | 0.48 | 0.82 | 1.11 | 0.56 |

Distribution Tap

| Year | Free Residual | | | Total Residual | | |
|------|---------------|------|------|----------------|------|------|
| | Avg | Max | Min | Avg | Max | Min |
| 2013 | 0.45 | 0.78 | 0.18 | 0.61 | 0.99 | 0.34 |
| 2012 | 0.44 | 0.90 | 0.13 | 0.59 | 1.05 | 0.30 |
| 2011 | 0.43 | 0.94 | 0.15 | 0.59 | 0.86 | 0.28 |
| 2010 | 0.41 | 0.82 | 0.07 | 0.58 | 0.98 | 0.20 |
| 2009 | 0.42 | 0.71 | 0.10 | 0.59 | 0.87 | 0.23 |

pH, Alkalinity and Hardness

Report of Water Quality Control Laboratory

pH

EPA standard is 7.1 - 7.9

| Year | Number of Tests | Raw Water | | | Plant Tap | | |
|------|-----------------|-----------|-----|-----|-----------|-----|-----|
| | | Avg | Max | Min | Avg | Max | Min |
| 2013 | 730 | 8.3 | 8.5 | 8.0 | 7.6 | 7.9 | 7.3 |
| 2012 | 732 | 8.3 | 8.5 | 8.1 | 7.6 | 7.9 | 7.6 |
| 2011 | 730 | 8.3 | 8.5 | 8.0 | 7.6 | 7.8 | 7.4 |
| 2010 | 730 | 8.3 | 8.6 | 7.9 | 7.6 | 7.8 | 7.3 |
| 2009 | 729 | 8.3 | 8.6 | 7.6 | 7.6 | 7.8 | 7.1 |

Alkalinity (ppm)

| Year | Number of Tests | Raw Water | | | Plant Tap | | |
|------|-----------------|-----------|-----|-----|-----------|-----|-----|
| | | Avg | Max | Min | Avg | Max | Min |
| 2013 | 730 | 105 | 112 | 94 | 98 | 108 | 90 |
| 2012 | 732 | 105 | 112 | 92 | 98 | 108 | 84 |
| 2011 | 730 | 106 | 116 | 93 | 99 | 110 | 74 |
| 2010 | 730 | 103 | 115 | 85 | 97 | 111 | 84 |
| 2009 | 730 | 104 | 118 | 91 | 97 | 119 | 80 |

Hardness (ppm as CaCO₃)

| Year | Number of Tests | Raw Water | | | Finished Water | | |
|------|-----------------|-----------|-----|-----|----------------|-----|-----|
| | | Avg | Max | Min | Avg | Max | Min |
| 2013 | 730 | 135 | 142 | 111 | 131 | 141 | 119 |
| 2012 | 732 | 136 | 149 | 124 | 132 | 149 | 134 |
| 2011 | 730 | 135 | 148 | 120 | 133 | 149 | 118 |
| 2010 | 730 | 133 | 151 | 122 | 132 | 151 | 120 |
| 2009 | 730 | 132 | 152 | 100 | 130 | 150 | 94 |

Detected Substances: 2013 Water Quality Data

| Substance | MCLG | Highest Allowed (MCL) | Highest Level Detected | Range of Levels Detected | Violation | Source of Contamination |
|---|---------------|--|---|---------------------------------|------------------|--|
| Turbidity (NTU) (Cloudiness) | NA | TT=Monitored by % exceeding 0.3 NTU and max allowed is 1 NTU | 100% of samples meet 0.3 NTU; 0.16 NTU Highest single measurement | 0.07 - 0.16 | NO | Soil runoff |
| Fluoride (ppm) | 4 | 4 | 0.9 | 0.9 - 1.1 | NO | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories. |
| Nitrate [measured as Nitrogen](ppm) | 10 | 10 | 0.4 | single sample | NO | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits |
| Sodium (ppm) | NA | NA | 7.5 | single sample | NO | Erosion from naturally occurring deposits |
| Barium (ppm) | 2 | 2 | 0.02 | single sample | NO | Discharge of drilling wastes; Discharge from metal refineries; Erosion of Natural deposits |
| Chromium, Total (ppm) | 0.1 | 0.1 | 0.0003 | 0.0002 - 0.0003 | NO | Discharge from steel and pulp mills; erosion of natural deposits |
| Total Coliform Bacteria | 0 | 5% of Monthly Samples are Positive | 1.2% | NA | NO | Naturally present in the environment |
| Combined Radium 226/228 (pCi/L) | 0 | 5 | 0.82 | single sample | NO | Erosion of natural deposits |
| Gross Alpha excluding Radon and Uranium (pCi/L) | 0 | 15 | 3.9 | single sample | NO | Erosion of natural deposits |
| Beta/Photon Emitters (mrem/yr) | 0 | 50 | 7.3 | single sample | NO | Decay of natural and man-made deposits |
| Cotinine (ppb) | NOT REGULATED | NOT REGULATED | 0.002 | Single Sample | NO | Nicotine metabolite/waste water discharge |
| Sulfate (ppm) | NOT REGULATED | USEPA National Secondary Standard of 250 | 25 | Single Sample | NO | Naturally occurring, coagulant residual |
| Disinfectants and Disinfection By-Products | MCLG | Highest Allowed (MCL) | Highest Level Detected | Range of Levels Detected | Violation | Source of Contamination |
| Total Trihalomethanes (ppb) | NA | 80 | 26 | 8.1 - 35.4 | NO | By-product of drinking water chlorination |
| Total Haloacetic Acids (ppb) | NA | 60 | 8 | 2.3 - 10.3 | NO | By-product of drinking water chlorination |
| Chlorine (ppm) | 4 MRLDG | 4 MRDL | 0.4 | 0.38 - 0.5 | NO | Water additive used to control microbes |

Detected Substances: 2013 Water Quality Data

| Lead & Copper | MCLG | Action Level (AL) | 90th Percentile | Range of Levels Detected | Violation | Source of Contamination |
|--|---------------|------------------------------|------------------------|---------------------------------|------------------|--|
| Lead (ppb) | 0 | 15 | 4.2 | <1 - 6.1 | NO | Corrosion of household plumbing systems; Erosion of natural deposits |
| Copper (ppm) | 1.3 | 1.3 | 0.18 | 0.0023-0.940 | NO | Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems |
| UCMR | MCLG | Highest Allowed (MCL) | Average | Range of Levels Detected | Violation | Source of Contamination |
| Chromium, Hexavalent (ppb)* (chromium-6) | NOT REGULATED | NOT REGULATED | 0.19 | 0.18 - 0.21 | NO | Naturally-occurring element; used in making steel or other alloys. Chromium-3 or -6 forms are used for chrome plating, dyes and pigments, leather tanning and wood preservation. |
| Molybdenum (ppb) | NOT REGULATED | NOT REGULATED | 1.1 | 1.0 - 1.1 | NO | Naturally occurring element found in ores and present in plants, animals and bacteria; commonly used form molybdenum trioxide used as a chemical reagent. |
| Strontium (ppb) | NOT REGULATED | NOT REGULATED | 115 | 110 - 120 | NO | Naturally occurring element; historically, commercial use of strontium has been in the faceplate glass of cathode-ray tube televisions to block x-ray emissions. |
| Vanadium (ppb) | NOT REGULATED | NOT REGULATED | 0.3 | 0.2 - 0.3 | NO | Naturally occurring elemental metal; used as vanadium pentoxide which is a chemical intermediate and a catalyst. |

Additional Information About Your Water

| Measured Parameter | Evanston Minimum | Evanston Maximum | Measured Parameter | Evanston Result |
|---------------------------------------|-------------------------|-------------------------|---------------------------|------------------------|
| pH (0-14 pH units) | 7.3 | 7.9 | Calcium (ppm) | 35 |
| Hardness (as mg CaCO ₃ /L) | 119 | 141 | Chloride (ppm) | 14 |
| Hardness (gpg) | 7.0 | 8.2 | Dissolved Solids (ppm) | 160 |
| Alkalinity (ppm) | 90 | 108 | Magnesium (ppm) | 12 |
| Raw Water Temperature °F | 33 | 76 | Potassium (ppm) | 1.5 |

Non-Detected Contaminants

2013 Water Quality Data

| Inorganic Contaminants | MCLG | MCL | UL MRL | Level Found |
|---|------|------|--------|-------------|
| ARSENIC (ppb) | none | 50 | 1 | nd |
| CADMIUM (ppb) | 5 | 5 | 1 | nd |
| CHROMIUM (ppb) | 100 | 100 | 2.0 | nd |
| CYANIDE (ppb) | 200 | 200 | 0.02 | nd |
| IRON (ppb) | n/a | 1000 | 0.02 | nd |
| MANGANESE (ppb) | n/a | 150 | 2 | nd |
| MERCURY (INORGANIC) (ppb) | 2 | 2 | 0.1 | nd |
| NICKEL | n/a | 100 | 1 | nd |
| SELENIUM (ppb) | 50 | 50 | 2 | nd |
| ANTIMONY (ppb) | 6 | 6 | 1 | nd |
| BERYLLIUM (ppb) | 4 | 4 | 0.3 | nd |
| THALLIUM (ppb) | 0.5 | 2 | 0.4 | nd |
| ZINC (ppb) | n/a | 5000 | 5 | nd |
| NITRITE (AS NITROGEN) (ppm) | 1 | 1 | 0.01 | nd |
| Synthetic Organic Contaminants | | | | |
| ENDRIN (ppb) | 2 | 2 | 0.1 | nd |
| BHC- GAMMA (LINDANE) | 200 | 200 | 0.1 | nd |
| METHOXYCHLOR (ppb) | 40 | 40 | 0.1 | nd |
| TOXAPHENE (ppb) | 0 | 3 | 1 | nd |
| DIQUAT (ppb) | 20 | 20 | 2 | nd |
| DALAPON (ppb) | 200 | 200 | 5 | nd |
| ENDOTHALL (ppb) | 100 | 100 | 9 | nd |
| DI(2-ETHYLHEXYL)ADIPATE (ppb) | 400 | 400 | 0.6 | nd |
| OXAMYL (VYDATE) (ppb) | 200 | 200 | 2 | nd |
| SIMAZINE (ppb) | 4 | 4 | 0.35 | nd |
| DI(2-ETHYLHEXYL)PHTHALATE (ppb) | 0 | 6 | 0.6 | nd |
| PICHLORAM (ppb) | 500 | 500 | 0.4 | nd |
| DINOSEB (ppb) | 7 | 7 | 1 | nd |
| HEXACHLOROCYCLOPENTADIENE (ppb) | 50 | 50 | 0.5 | nd |
| ALDICARB SULFOXIDE | n/a | n/a | 1 | nd |
| ALDICARB SULFONE | n/a | n/a | 1 | nd |
| CARBOFURAN (ppb) | 40 | 40 | 0.9 | nd |
| ALDICARB | n/a | n/a | 1 | nd |
| ATRAZINE (ppb) | 3 | 3 | 0.3 | nd |
| ALACHLOR (LASSO)(ppb) | 0 | 2 | 0.2 | nd |
| HEPTACHLOR | 0 | 100 | 0.04 | nd |
| HEPTACHLOR EPOXIDE (ppt) | 0 | 100 | 0.02 | nd |
| DIELDRIN | n/a | 1 | 0.05 | nd |
| 2,4-Dichloro-Phenoxyacetic Acid (2,4-D) (ppb) | 10 | 10 | 1 | nd |
| 2,4,5-TP (SILVEX) (ppb) | 50 | 50 | 1 | nd |
| HEXACHLOROBENZENE (ppb) | 0 | 1 | 0.1 | nd |
| BENZO (A) PYRENE (ppb) | 0 | 200 | 0.1 | nd |
| PENTACHLOROPHENOL (PCP) (ppb) | 0 | 1 | 0.4 | nd |
| ALDRIN (ppb) | n/a | 1 | 0.05 | nd |
| POLYCHLORINATED BIPHENYLS (PCB) (ppb) | 0 | 500 | | nd |
| TOTAL DDT (ppb) | n/a | 50* | 1 | nd |
| 1,2 DIBROMO3-CHLOROPROPANE (DBCP) (ppb) | 0 | 0.2 | 0.02 | nd |
| ETHYLENE DIBROMIDE (EDB) (ppb) | 0 | 50 | 0.01 | nd |
| CHLORDANE (ppb) | 0 | 2 | 0.2 | nd |

Non-Detected Contaminants

2012 Water Quality Data

| Radionuclides | MCLG | MCL | UL MRL | Level Found |
|-----------------------------------|-------------|------------|---------------|--------------------|
| COMBINED RADIUM - 226,228 (pCi/L) | 0 | 5 | | nd |

| THM/HAA5 | MCLG | MCL | UL MRL | Level Found |
|----------------------------|-------------|------------|---------------|--------------------|
| MONOCHLORACETIC ACID (ppb) | 70 | 70 | 2.0 | nd |
| MONOBROMOACETIC ACID (ppb) | na | na | 1.0 | nd |
| DIBROMOACETIC ACID (ppb) | na | na | 1.0 | nd |

| UCMR3 (ppb) collected 8/13 & 11/13 | MCLG | MCL | UL MRL | Level Found |
|---|-------------|------------|---------------|--------------------|
| Chlorate | na | na | 20 | nd |
| 1,4 Dioxane | na | na | 0.07 | nd |
| Bromochloromethane | na | na | 0.06 | nd |
| Bromomethane | na | na | 0.2 | nd |
| 1,3- Butadiene | na | na | 0.1 | nd |
| Chlorodifluoromethane | na | na | 0.08 | nd |
| Chyloromethane | na | na | 0.2 | nd |
| 1,1 Dichloroethane | na | na | 0.03 | nd |
| 1,2,3, Trichloropropane | na | na | 0.03 | nd |
| Perfluorobutanesulfonic acid (PFBS) | na | na | 0.09 | nd |
| Perfluoroheptanoic acid (PFHpA) | na | na | 0.01 | nd |
| Perfluorohexanesulfonic acid (PFHxS) | na | na | 0.03 | nd |
| Perfluorononanoic acid (PFNA) | na | na | 0.02 | nd |
| Perfluorooctane sulfonate (PFOS) | na | na | 0.04 | nd |
| Perfluorooctanoic acid (PFOA) | na | na | 0.02 | nd |
| Cobalt | na | na | 1 | nd |

| Unregulated Contaminants | MCLG | MCL | UL MRL | Level Found |
|--|-------------|------------|---------------|--------------------|
| Bisphenol A (ppb) | na | na | 0.1 | nd |
| Nonylphenol, isomer mix (ppb) | na | na | 0.5 | nd |
| 4-n-Octylphenol (ppb) | na | na | 0.5 | nd |
| 4-tert-Octylphenol (ppb) | na | na | 0.5 | nd |
| Pentachlorophenol (ppb) | na | na | 0.1 | nd |
| Phenylphenol (ppb) | na | na | 0.1 | nd |
| Tetrabromobisphenol A (ppb) | na | na | 0.1 | nd |
| 2,4,6-Trichlorophenol (ppb) | na | na | 0.1 | nd |
| Pharmaceutically Active Compounds Positive | na | na | varies | nd |
| Pharmaceutically Active Compounds Negative | na | na | varies | nd |

MCL= Maximum Contaminant Level

MCLG = Maximum Contaminant Level Goal

UL MRL= Underwriters Laboratories Minimum Reporting Level

ND = Not Detected

Lead and Copper Statement

Report of Water Quality Control Laboratory

There is no detectable lead in the water produced by the City of Evanston's water treatment plant. Lead enters the water from lead solder and/or lead pipes in water services, or through plumbing fixtures. To minimize contamination resulting from corrosion, the EPA established a lead action level of 15 parts per billion (ppb) in 1992. The 90th percentile result of samples analyzed for lead and copper content in homes with lead pipes must be less than the action levels of 15 ppb and 1.3 ppm, respectively.

Lead and copper sampling is performed every three years in compliance with state law. In 2011, Evanston sampled water from 30 homes with lead service lines and analyzed them for lead and copper content. All results were below the action levels. The 90th percentile level for lead in these samples was 4.2 ppb. The 90th percentile level for copper was 0.18 ppm.

Definitions and General Explanations

Action Level – The concentration of a contaminant, which, if exceeded, triggers treatment or other required actions by the water supply.

Disinfection By-Products – Total Trihalomethanes and Total Haloacetic Acids are used to regulate the amount of allowable by-products of chlorination.

EPA – Environmental Protection Agency

Fluoride – The Illinois Department of Public Health recommends an optimal fluoride range of 0.9 to 1.2 ppm

Lead and Copper – There is no detectable lead in the water provided to the Evanston community. Lead enters the water from lead solder, lead pipes, or plumbing fixtures. To minimize contamination resulting from corrosion, the EPA established a lead action level of 15 parts per billion (ppb) in 1992. The 90th percentile result of samples analyzed for lead and copper content in homes with lead pipes must be less than the action level of 15 ppb and 1.3 ppm respectively.

MCL – Maximum Contaminant Level, the highest level of a contaminant that is allowed in drinking water. A MCL is set as close to a MCLG as feasible using the best available treatment technology.

MCLG – Maximum Contaminant Level Goal, the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

mg CaCO₃/L – milligrams of calcium carbonate per liter.

mrem/yr – Millirems Per Year. A measure of radiation absorbed by the body.

MRDL – Maximum Residual Disinfection Level. The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG – Maximum Residual Disinfection Level Goal. The level of disinfectant in drinking water below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA – Not applicable.

NTU – Nephelometric Turbidity Units. A measure of the cloudiness of water.

pCi/L – Picocuries per liter. A measure of radioactivity.

ppm – Parts per million. A measure of the concentration of a substance in water. An equivalent unit of measurement is milligrams per liter (mg/L).

ppb – Parts per billion. A measure of the concentration of a substance in water. An equivalent unit of measurement is micrograms per liter (µg/L).


Sodium – There is not a state or federal MCL for sodium. Sodium levels below 20 mg/L (ppm) are not considered to be a public health issue.

TT – Treatment Technique. A required process to reduce the level of a contaminant.

Turbidity – A measurement of the cloudiness of the water caused by suspended particles. This is monitored because it is a good indicator of water quality as well as the effectiveness of the filtration and disinfection processes.

TOC – Total Organic Carbon. The Evanston Water Supply monitored the percentage of TOC removal quarterly and met all TOC removal requirements set by the EPA.

Distribution



In 1897, the plant received a remodeling and enlargement, as well as a third Holly engine with a capacity of 12 million gallons a day. In 1914, a filter plant was built, making Evanston the first city along Lake Michigan with water treatment. The decline in typhoid and dysentery rates as a result of clean water helped spur Evanston's growth in the years to come.

Fire Hydrants



System Data and Maintenance*

Hydrants Tested

| for Proper Operation | 2009 | 2010 | 2011 | 2012 | 2013 |
|----------------------|-------|-------|-------|-------|-------|
| Fire Department | 1,630 | 1,394 | 1,410 | 1,400 | 1,417 |
| Utilities Department | 84 | 92 | 126 | 42 | 22 |

Hydrant Installation and Maintenance

| | 2009 | 2010 | 2011 | 2012 | 2013 |
|-----------------|------|------|------|------|------|
| Installed (new) | 6 | 11 | 19 | 10 | 18 |
| Replaced | 18 | 19 | 22 | 17 | 22 |
| Repaired | 119 | 114 | 176 | 73 | 175 |



* All work completed by Utilities Department staff unless otherwise noted.

** Changes from year to year are primarily due to removal/addition of hydrants during water main replacement projects, and GIS map corrections.


Valves

System Data and Maintenance*

| Valves Turned for Proper Operation | 2009 | 2010 | 2011 | 2012 | 2013 |
|------------------------------------|------|-------|------|-------|-------|
| In-House | 254 | 1,400 | 807 | 1,071 | 1,117 |
| Contractor | 0 | 0 | 0 | 0 | 0 |

| Valve Installation and Maintenance | 2009 | 2010 | 2011 | 2012 | 2013 |
|------------------------------------|------|------|------|------|------|
| Installed (new) | 14 | 12 | 10 | 11 | 14 |
| Replaced | 20 | 36 | 25 | 26 | 44 |
| Repaired | 21 | 44 | 24 | 38 | 41 |

| Number of Distribution Valves by Size | 2009 | 2010 | 2011 | 2012 | 2013 |
|---------------------------------------|-------|-------|-------|-------|-------|
| 3" | 1 | 1 | 1 | 1 | 1 |
| 4" | 34 | 30 | 30 | 29 | 27 |
| 6" | 1050 | 1033 | 1,021 | 1,011 | 996 |
| 8" | 435 | 452 | 469 | 484 | 492 |
| 10" | 183 | 183 | 183 | 185 | 183 |
| 12" | 211 | 222 | 227 | 235 | 243 |
| 14" | 2 | 2 | 2 | 2 | 2 |
| 16" | 49 | 49 | 49 | 49 | 46 |
| 18" | 4 | 4 | 4 | 4 | 4 |
| 20" | 2 | 1 | 1 | 2 | 2 |
| 24" | 30 | 30 | 30 | 30 | 33 |
| 30" | 11 | 11 | 11 | 11 | 12 |
| 36" | 12 | 12 | 12 | 12 | 12 |
| 42" | 2 | 2 | 2 | 2 | 2 |
| 48" | 2 | 2 | 2 | 2 | 2 |
| Total | 2,028 | 2,034 | 2,044 | 2,059 | 2,057 |



* All work completed by Utilities Department staff unless otherwise noted.

** Valves are not accessible for field verification of age and other attributes because they are buried beneath paved surfaces. These valves are only accessible for operation from the surface.

Water Mains

System Data and Maintenance*

Water Main Installation (lineal feet installed)


| | 2009 | 2010 | 2011 | 2012 | 2013 |
|------------|------|-------|-------|-------|-------|
| In-House | 7 | 0 | 0 | 181 | 50 |
| Contractor | 0 | 7,712 | 7,235 | 9,868 | 8,870 |

Water Main Break Repairs

| | 2009 | 2010 | 2011 | 2012 | 2013 |
|-------------|------|------|------|------|------|
| Blow-Out | 17 | 26 | 16 | 56 | 21 |
| Shear Break | 10 | 10 | 11 | 8 | 30 |
| Damage | 0 | 0 | 0 | 2 | 3 |
| Total | 27 | 36 | 27 | 66 | 54 |

Water Main Sizes** (length in miles)

| | 2009 | 2010 | 2011 | 2012 | 2013 |
|-------|--------|--------|--------|--------|--------|
| 3" | 0.15 | 0.15 | 0.15 | 0.15 | 0.12 |
| 4" | 2.38 | 1.95 | 1.95 | 1.68 | 1.55 |
| 6" | 79.71 | 78.66 | 77.49 | 76.02 | 74.99 |
| 8" | 29.06 | 25.72 | 26.69 | 27.62 | 28.35 |
| 10" | 12.43 | 12.46 | 12.46 | 12.47 | 12.30 |
| 12" | 16.05 | 16.55 | 16.88 | 17.42 | 17.73 |
| 14" | 0.37 | 0.37 | 0.37 | 0.37 | 0.37 |
| 16" | 6.35 | 6.35 | 6.35 | 6.51 | 6.25 |
| 18" | 0.83 | 0.83 | 0.83 | 0.83 | 0.83 |
| 20" | 0.56 | 0.49 | 0.56 | 0.56 | 0.56 |
| 24" | 8.25 | 8.25 | 8.30 | 8.30 | 8.60 |
| 30" | 1.69 | 1.69 | 1.69 | 1.69 | 1.69 |
| 36" | 3.29 | 3.30 | 3.30 | 3.30 | 3.30 |
| 42" | 0.04 | 0.04 | 0.04 | 0.04 | 0.04 |
| 48" | 0.69 | 0.68 | 0.68 | 0.68 | 0.68 |
| Total | 161.85 | 157.48 | 157.73 | 157.63 | 157.35 |



* All work completed by Utilities Department staff unless otherwise noted.

** Changes from year to year are primarily due to removal/addition of water main during water main replacement projects and GIS map corrections.

Water Services

System Data and Maintenance*


Number of Water Service Accounts: 14,861**

Water Service Installation and Maintenance

| | 2009 | 2010 | 2011 | 2012 | 2013 |
|---------------------------------|------|------|------|------|------|
| New Services Installed | 48 | 31 | 19 | 4 | 2 |
| Service Taps Replaced*** | - | - | - | 55 | 28 |
| Services Replaced by Contractor | - | - | - | - | 188 |
| Service Leaks Repaired | 26 | 26 | 22 | 14 | 34 |

Breakdown of In-House Maintenance Costs****

| | 2009 | 2010 | 2011 | 2012 | 2013 |
|--------------------------|------------------|------------------|------------------|------------------|------------------|
| Water Mains | \$166,657 | \$171,124 | \$145,934 | \$274,946 | \$213,075 |
| Fire Hydrants | \$194,376 | \$38,467 | \$207,625 | \$95,065 | \$109,048 |
| Water Services | \$127,230 | \$189,912 | \$211,007 | \$135,193 | \$159,592 |
| Valves | \$117,947 | \$202,871 | \$76,172 | \$102,763 | \$128,645 |
| Snow & Ice Removal | \$22,794 | \$70,745 | \$59,479 | \$24,085 | \$42,384 |
| Assist Contractor | \$40,067 | \$42,597 | \$43,969 | \$70,848 | \$69,516 |
| JULIE Locates | \$34,210 | \$34,560 | \$58,975 | \$62,845 | \$73,519 |
| Equip/Facility Maint. | \$55,004 | \$67,348 | \$85,559 | \$62,757 | \$85,631 |
| Assist Other City Depts. | \$29,180 | \$46,640 | \$21,390 | \$16,053 | \$11,364 |
| Assist W&S Divisions | \$25,583 | \$18,067 | \$11,433 | \$13,739 | \$10,811 |
| Safety & Training | \$9,595 | \$86,878 | \$19,270 | \$10,853 | \$18,883 |
| Misc. | \$11,984 | \$7,666 | \$10,337 | \$25,370 | \$45,422 |
| Total | \$834,627 | \$976,874 | \$951,150 | \$894,518 | \$967,890 |




* All work completed by Utilities Department staff unless otherwise noted.

** Includes metered domestic water service accounts and unmetered fire service accounts.

*** Differentiation of replacement of existing water services from new water service installations began in 2012.

**** Costs fluctuate from year to year due to changes in maintenance needs and prioritization of repair projects.

Water Mains Installed




Cross Connection Control

A cross connection is a point in a plumbing system where the potable (safe, drinkable) water supply is connected to a non-potable (polluted or untreated) source. A cross connection exists whenever the drinking water system is or could be connected to any non-potable source. If cross connections are not properly protected and there is a drop in pressure, untreated sources and dirt can be pulled into household plumbing systems.

The State of Illinois and the City of Evanston require mandatory backflow protection on certain households and facilities where high health-hazard-type cross connections are normally found. Underground lawn sprinkling systems, fire protection systems, hospitals and health clinics, mortuaries, laboratories, food and beverage processing and car washes are just a few of the locations where backflow prevention is necessary to protect the quality of our public water supply.

In 2008, the Utilities Department hired a plumbing inspector to manage the City's cross connection control program. Since that time, over 2,000 backflow prevention devices have been added to the City's inventory and are now regularly inspected for compliance with State and City codes. An annual tracking system enables the City to ensure these devices are properly maintained throughout their life cycle. This helps keep the high quality drinking water produced by the City's water treatment plant safe to drink after entering the water distribution system.

| Year | Backflow Prevention Devices Certified Annually |
|----------|--|
| Pre-2009 | 2,279 |
| 2009 | 2,061 |
| 2010 | 2,292 |
| 2011 | 2,609 |
| 2012 | 2,786 |
| 2013 | 3,356 |




Metering



In 1944, Skokie requested a direct water supply, which Evanston provided in the form of a direct pressure pipeline. By 1948, the growth of Skokie and Evanston made expanding the water plant a necessity. The expansion included a new all-electric high lift pumping station, new mixing and settling basins, a chemical building and laboratory, dry chemical feeders, and the addition of six 4 mgd filters, bringing the total filter capacity to 48 mgd. In 1950, the steam plant was shut down, giving way entirely to electric pumps with two backup gasoline engines.

Fixed Network Meter Reading System



How it works:

- The Meter Information Unit (MIU) is attached to every water meter in Evanston. Each MTU contains a radio transmitter that, twice per day, broadcasts the meter reading.
- The Data Collector Unit (DCU) receives the meter readings from the MTUs and stores this data. Evanston currently has 6 DCUs located on various buildings throughout the community. Each DCU sends its meter reading information to the Network Control System at the Water Treatment Plant on a daily basis.
- The Network Control System supports customer service and system management activities and transfers the meter readings to the billing system.

Transmitter Tower Locations



Water Meter Inventory

Water is billed bi-monthly in units of 100 cubic feet (CCF). The minimum service charge every two months is based on water meter size as follows:

| Meter Size | Number of Meters |
|------------|------------------|
| 5/8" | 11,796 |
| 3/4" | 807 |
| 1" | 1,047 |
| 1.5" | 251 |
| 2" | 461 |
| 3" | 55 |
| 4" | 25 |
| 6" | 3 |
| 8" | 4 |
| Total | 14,449 |

Water Rates to Evanston Customers

Water is billed bi-monthly in units of 100 cubic feet (CCF). The minimum service charge every two months is based on water meter size as follows:

| Meter Size | Minimum Charge Effective 7/1/2013 |
|-------------|-----------------------------------|
| 5/8" & 3/4" | \$6.43 |
| 1" | \$12.84 |
| 1 1/2" | \$24.03 |
| 2" | \$37.83 |
| 3" | \$66.62 |
| 4" | \$106.72 |
| 6" | \$188.20 |
| 8" | \$318.59 |

The minimum demand charge includes the first five hundred cubic feet (5 CCF) of water consumed every two months, which is roughly equivalent to 3,740 gallons of water.




Water usage over the minimum is billed at \$1.80 per CCF effective 7/1/2013. This is equivalent to a rate of \$2.41 per 1,000 gallons.

Water Service Accounts

Billed by Category and Water Usage for 2013

| Category | Number of Accounts | 2013 Usage (CCF)* |
|---------------------------------|--------------------|-------------------|
| Metered Water Services | | |
| Single-Family | 10,858 | 1,010,613 |
| Multi-Family | 2,497 | 1,178,975 |
| Commercial | 940 | 1,105,077 |
| Industry | 35 | 12,392 |
| City | 32 | 14,509 |
| Park | 53 | 4,407 |
| School | 34 | 42,992 |
| Subtotal | 14,449 | 3,368,965 |
| Unmetered Water Services | | |
| Fire Services** | 453 | - |
| Totals | 14,902 | 3,368,965 |


Water Service Accounts by Category:



* Water usage is metered in units of 100 cubic feet (CCF). 1 CCF is approximately 748 gallons

** Fire services are not metered. They are billed a flat charge twice per year.

2013 Water Usage by Evanston Customers




Sewer



More improvements occurred throughout the 1950s and 1960s, including eliminating all pollution to Lake Michigan from the water treatment plant and increasing the plant's total pumping capacity to 147 mgd. In 1980, Evanston signed a contract to provide water to the Northwest Water Commission, consisting of the municipalities of Arlington Heights, Buffalo Grove, Palatine, and Wheeling. From 1980 to 1985, the Evanston utilities underwent major capital improvements, updating many of the systems and building two standpipes for the northern and southern parts of Evanston.

Sewer Revenues*

| | 2012 | 2013 |
|----------------------------|---------------------|---------------------|
| Operations | \$14,115,210 | \$13,494,318 |
| Debt Proceeds | \$4,003,385 | \$2,000,000 |
| Investment Earnings | \$2,962 | \$1,271 |
| Miscellaneous** | \$0 | \$860,353 |
| Total Sewer Revenue | \$18,121,557 | \$16,355,942 |




* Financial data are based on actual expenses and do not include audit adjustments such as depreciation and inventory. For audited financial records, see the Comprehensive Annual Financial Report for the City of Evanston, <http://www.cityofevanston.org/transparency/budget-financial-reports/>.

** Miscellaneous Revenue includes cross connection control fees, investment earnings, property rental, interest income, fees, grants, insurance reimbursement, phosphate sales, and merchandise sales. The

Sewer Operating & Maintenance Expenses*


| | 2012 | 2013 |
|-------------------------|---------------------|---------------------|
| Sewer Operations | \$1,866,650 | \$2,127,810 |
| Other Oper. Expenses | \$48,100 | \$23,300 |
| Interfund Transfers | \$529,403 | \$602,399 |
| Capital Outlay | \$18,000 | \$17,803 |
| Annual Rehab Programs** | \$753,000 | \$1,000,000 |
| Debt Service | \$14,242,252 | \$11,542,740 |
| Total | \$17,457,405 | \$15,314,052 |




* Financial data are based on actual expenses and do not include audit adjustments such as depreciation and inventory. For audited financial records, see the Comprehensive Annual Financial Report for the City of Evanston, <http://www.cityofevanston.org/transparency/budget-financial-reports/>.

**Includes CIPP sewer rehabilitation, drainage structure replacement, stormwater management improvements, and emergency sewer repairs


Major Combined Sewer System



Major Relief Sewer System



Major Storm Sewer System




Sewer Mains

System Data and Maintenance*

| Sewer Length by Type | Pipe Length (miles) | | | | |
|----------------------|---------------------|--------|--------|--------|--------|
| | 2009 | 2010 | 2011 | 2012 | 2013 |
| Combined Sewer | 143.08 | 142.91 | 143.60 | 143.78 | 143.93 |
| Relief Sewer | 48.10 | 50.51 | 51.51 | 51.78 | 52.65 |
| Storm Sewer | 18.48 | 16.11 | 16.21 | 16.21 | 16.31 |
| Total Length | 209.66 | 209.53 | 211.32 | 211.77 | 212.89 |

| Sewer Installation and Maintenance | Pipe Length (feet) | | | | |
|------------------------------------|--------------------|---------|---------|---------|---------|
| | 2009 | 2010 | 2011 | 2012 | 2013 |
| Installed (new) | 28 | 430 | 424 | 239 | 1,682 |
| Replaced | 17 | 86 | 0 | 0 | 0 |
| CIPP Rehabilitation (Lining) | 7,741 | 2,081 | 6,997 | 8,850 | 15,995 |
| Spot Repair | 4,444 | 1,845 | 3,280 | 1,183 | 4,804 |
| Clean - Hydroflush | 125,505 | 262,451 | 247,195 | 242,791 | 180,309 |
| Clean - Root Cut | 2,252 | 13,330 | 17,543 | 5,372 | 7,657 |
| Inspection - General | 34,150 | 38,527 | 25,354 | 19,695 | 21,421 |
| Inspection - Televised | 59,654 | 65,933 | 81,502 | 83,942 | 78,022 |
| Inspection - Storm-related** | 33,394 | 4,043 | 2,070 | 0 | 1,981 |



* All work performed by Utilities Department except CIPP Rehabilitation (Lining).

** Inspection of City sewer mains as a result of sewer surcharge during or after a wet weather event, and inspection of storm sewer outfalls into the North Shore Channel.

*** Mains of unknown age were installed prior to detailed record keeping on sewer installations.

Length of Sewer Mains

By Type and Diameter

| Diameter | Combined Sewer | | Relief Sewer | | Storm Sewer | |
|---------------|----------------|---------------|----------------|--------------|---------------|--------------|
| | Feet | Miles | Feet | Miles | Feet | Miles |
| <6" | 3,136 | 0.59 | 243 | 0.05 | 0 | 0.00 |
| 6" | 296 | 0.06 | 0 | 0.00 | 0 | 0.00 |
| 8" | 19,541 | 3.70 | 9,851 | 1.87 | 2,177 | 0.41 |
| 9" | 123,331 | 23.36 | 7,229 | 1.37 | 1,229 | 0.23 |
| 10" | 109,711 | 20.78 | 26,169 | 4.96 | 10,441 | 1.98 |
| 12" | 226,233 | 42.85 | 24,894 | 4.71 | 9,883 | 1.87 |
| 14" | 1,019 | 0.19 | 0 | 0.00 | 0 | 0.00 |
| 15" | 92,731 | 17.56 | 5,649 | 1.07 | 5,249 | 0.99 |
| 16" | 2,085 | 0.39 | 6,097 | 1.15 | 724 | 0.14 |
| 18" | 60,979 | 11.55 | 16,511 | 3.13 | 7,695 | 1.46 |
| 20" | 8,410 | 1.59 | 127 | 0.02 | 0 | 0.00 |
| 21" | 15,046 | 2.85 | 2,747 | 0.52 | 1,910 | 0.36 |
| 22" | 858 | 0.16 | 0 | 0.00 | 0 | 0.00 |
| 24" | 20,674 | 3.92 | 46,353 | 8.78 | 15,959 | 3.02 |
| 27" | 6,434 | 1.22 | 6,373 | 1.21 | 3,240 | 0.61 |
| 30" | 6,973 | 1.32 | 19,107 | 3.62 | 3,913 | 0.74 |
| 33" | 3,771 | 0.71 | 1,309 | 0.25 | 482 | 0.09 |
| 36" | 19,769 | 3.74 | 18,386 | 3.48 | 6,730 | 1.27 |
| 39" | 421 | 0.08 | 0 | 0.00 | 0 | 0.00 |
| 40" | 377 | 0.07 | 0 | 0.00 | 0 | 0.00 |
| 42" | 6,700 | 1.27 | 12,266 | 2.32 | 3,570 | 0.68 |
| 45" | 1,029 | 0.19 | 0 | 0.00 | 0 | 0.00 |
| 48" | 13,402 | 2.54 | 22,580 | 4.28 | 7,966 | 1.51 |
| 51" | 1,104 | 0.21 | 0 | 0.00 | 0 | 0.00 |
| 54" | 1,985 | 0.38 | 3,159 | 0.60 | 609 | 0.12 |
| 57" | 784 | 0.15 | 0 | 0.00 | 0 | 0.00 |
| 60" | 7,202 | 1.36 | 4,916 | 0.93 | 3,633 | 0.69 |
| 72" | 4,114 | 0.78 | 11,661 | 2.21 | 0 | 0.00 |
| 78" | 0 | 0.00 | 5,440 | 1.03 | 0 | 0.00 |
| 84" | 0 | 0.00 | 88 | 0.02 | 0 | 0.00 |
| 96" | 0 | 0.00 | 2,366 | 0.45 | 0 | 0.00 |
| 108" | 0 | 0.00 | 5,025 | 0.95 | 0 | 0.00 |
| 113" | 0 | 0.00 | 9,275 | 1.76 | 0 | 0.00 |
| 120" | 0 | 0.00 | 7,340 | 1.39 | 0 | 0.00 |
| Unknown | 1,844 | 0.35 | 2,833 | 0.54 | 691 | 0.13 |
| Totals | 759,955 | 143.93 | 277,992 | 52.65 | 86,102 | 16.31 |

Total Sewer Main Length: 212.89 miles

Sewer Structures

System Data and Maintenance


| Number of Sewer Structures | 2009 | 2010 | 2011 | 2012 | 2013 |
|-----------------------------------|---------------|---------------|---------------|---------------|---------------|
| Manholes | 5,540 | 5,453 | 5,507 | 5,532 | 5,561 |
| Inlets | 2,819 | 2,826 | 2,902 | 2,927 | 2,973 |
| Catch Basins | 6,214 | 6,217 | 6,159 | 6,179 | 6,203 |
| Total | 14,573 | 14,496 | 14,568 | 14,638 | 14,737 |

| Sewer Structure Installation & Maintenance | 2009 | 2010 | 2011 | 2012 | 2013 |
|---|-------|-------|-------|-------|-------|
| Installed (new) | 4 | 3 | 7 | 2 | 16 |
| Replaced | 25 | 17 | 12 | 39 | 5 |
| Repair | 151 | 119 | 96 | 133 | 87 |
| Clean | 3,157 | 2,750 | 2,428 | 4,109 | 2,732 |
| Inspect - General | 208 | 325 | 286 | 411 | 327 |
| Inspect - Storm-Related* | 943 | 562 | 835 | 479 | 1,001 |

* Inspection of City drainage structures as a result of street or alley flooding during or after a wet weather event.

Breakdown of In-House Maintenance Costs*


| Description | 2009 | 2010 | 2011 | 2012 | 2013 |
|-------------------------|--------------------|--------------------|--------------------|--------------------|--------------------|
| Sewer Mains | \$484,385 | \$414,913 | \$616,921 | \$413,919 | \$449,960 |
| Sewer Structures | \$506,297 | \$415,475 | \$474,164 | \$615,415 | \$423,665 |
| Equip/Facility Maint. | \$157,495 | \$164,813 | \$208,299 | \$161,460 | \$176,489 |
| Assist W&S Divisions | \$45,462 | \$62,576 | \$49,930 | \$45,855 | \$48,692 |
| Snow & Ice Removal | \$26,001 | \$149,395 | \$132,370 | \$31,396 | \$66,675 |
| Assist Contractors | \$3,401 | \$3,190 | \$8,847 | \$18,240 | \$39,542 |
| Assist Other City Depts | \$25,590 | \$29,250 | \$29,093 | \$57,269 | \$13,569 |
| Safety & Training | \$22,687 | \$10,973 | \$15,857 | \$21,321 | \$15,233 |
| JULIE Locates | \$2,394 | \$1,622 | \$2,155 | \$1,300 | \$135 |
| Miscellaneous | \$17,702 | \$12,598 | \$9,799 | \$5,966 | \$6,808 |
| Total | \$1,291,413 | \$1,264,804 | \$1,547,437 | \$1,372,141 | \$1,240,768 |



* All work completed by Utilities Department staff unless otherwise noted.

** Costs fluctuate from year to year due to changes in maintenance needs and prioritization of repair projects.

Sewer Mains Rehabilitated (Lined)



Annual_Report_SEWERLINED.mxd

9/30/2014