



**Request for Proposal
#22-01**

Water Meter Replacement Project Phase II

ADDENDUM No. 1

February 15, 2022

Any and all changes to the Request for Proposal are valid only if they are included by written addendum to all potential respondents, which will be emailed prior to the proposal due date to all who are known to have received a complete Request for Proposal. Each respondent must acknowledge receipt of any addenda by indicating in its submission. Each respondent, by acknowledging receipt of addenda, is responsible for the contents of the addenda and any changes to the bid therein. Failure to acknowledge receipt of addenda may cause the submission to be rejected. If any language or figures contained in this addendum are in conflict with the original document, this addendum shall prevail.

This addendum consists of the following:

1. Addendum No.1 is attached and consists of a total of three (3) pages including this cover sheet.

Please contact me at 847-866-2971 or jostman@cityofevanston.org with any further questions or comments.

Sincerely,

Jillian Ostman
Purchasing Specialist



Request for Proposal #22-01

Water Meter Replacement Project Phase II

ADDENDUM No. 1

February 15, 2022

This addendum forms a part of the RFP Documents for RFP #22-01 and modifies these documents. This addendum consists of the following:

General:

1. On August 27, 2021 Gov. JB Pritzker signed into law the Lead Service Line Replacement and Notification Act, making Illinois the third state (Michigan and New Jersey) in the nation to require full replacement of lead drinking water pipes. The effective date of Public Act 102-0613 was 1/1/2022.

During the course of the contractor replacing a water meter that is connected to a lead or galvanized water service pipe, if the contractor breaks the water service pipe, the contractor will be responsible for replacing the entire private side lead service pipe at the contractors cost. Repairs to lead or galvanized water service pipes are no longer allowed by State of Illinois law. The contractor must immediately notify the community water supply staff and the property owner to begin the process of replacing the entire service line (the City of Evanston will replace the public owned portion of the service line). Replacement of the private portion of the lead service line must occur within 30 days or 120 days in the event of weather or other circumstances beyond reasonable control that prohibits construction.

If complete repair of a lead service line cannot be completed due to denial by the property owner, the community water supply shall request the affected property owner to sign a waiver developed by the Illinois Department of Public Health. If a property owner of a nonresidential

building or residence operating as rental properties denies a complete lead service line replacement, the property owner shall be responsible for installing and maintaining point-of-use filters certified by an accredited third-party certification body to NSF/ANSI 53 and NSF/ANSI 42 for the reduction of lead and particulate at all fixtures intended to supply water for the purposes of drinking, food preparation, or making baby formula. The filters shall continue to be supplied by the property owner until such time that the property owner has affected the remaining portions of the lead service line to be replaced.

Clarification:

1. Responses will only be accepted electronically via E-bidding through DemandStar (www.demandstar.com). It is highly recommended to pre-register prior to the 2:00 P.M. due date to ensure all documentation is uploaded and received properly.

NO PROPOSALS WILL BE ACCEPTED AFTER THE SUMMITTAL DEADLINE.

Note: Acknowledgment of this Addendum is required in the Submittal.