



Butler and Twiggs Park Electrical Improvements

Bid # 22-55

ADDENDUM No. 1

August 24, 2022

Any and all changes to the Contract Document are valid only if they are included by written addendum to all potential respondents, which will be mailed, emailed and/or faxed prior to the bid due date to all who are known to have received a complete bid document. Each respondent must acknowledge receipt of any addenda by indicating on the Bid Form. Each respondent, by acknowledging receipt of any addenda, is responsible for the contents of the addenda and any changes to the bid proposal therein. Failure to acknowledge receipt of any addenda may cause the proposal to be rejected. If any language or figures contained in this addendum are in conflict with the original document, this addendum shall prevail.

This addendum consists of the following:

1. Addendum Number One (1) is attached and consists of a total of two (2) pages including this cover sheet. Any changes to the drawings or specifications noted within Addendum Number One (1) will be reflected in subsequent drawing issues.

Please feel free to call (847-866-2910) or email (lithomas@cityofevanston.org) with any questions or comments.

Sincerely,

Linda Thomas
Purchasing Specialist

Butler and Twiggs Park Electrical Improvements

Bid # 22-55

ADDENDUM No. 1

August 24, 2022

This addendum forms a part of the Specifications and Bid Documents for Bid #22-55 and modifies these documents. This addendum consists of the following:

Drawings

1. The specification for Fixture F2 has been changed. Fixture F2 is an LED retrofit for the existing lighting units at Twiggs Park. The existing lighting units were installed in two phases between 1999 and 2008. As a result the manufacturer has identified the following two retrofit fixture types for use on this project:

1999, quantity 20

LEDGINE-58581-30-DMS50-35W32LED3K-LE5F-UNV-DMG

2008, quantity 12

LEDGINE-109762-60-DMS50-55W32LED3K-LE5F-UNV-DMG-FAWS

The desired lumen output for each fixture is approximately 5000 lumens. As a result, the 2008 retrofit fixtures shall be adjusted in the field to the 35 watt setting to match the lumen output of the 1999 retrofit fixture.

Note: Acknowledgment of this Addendum is required in the Bid.