

BID # 22-56

Sewer Inspection, 24-inch Diameter and Larger

ADDENDUM No. 1

September 12, 2022

Any and all changes to the Bid are valid only if they are included by written addendum to all potential respondents, which will be emailed prior to the Bid due date. Each respondent must acknowledge receipt of any addenda by indicating in its Bid. Each respondent, by acknowledging receipt of addenda, is responsible for the contents of the addenda and any changes to the bid therein. Failure to acknowledge receipt of addenda may cause the Bid to be rejected. If any language or figures contained in this addendum are in conflict with the original Bid Document, this addendum shall prevail.

This addendum consists of the following:

1. Addendum No. 1 is attached and consists of a total of two pages including this cover sheet,

Please contact me at (847-866-2971) or JohnGonzalez@cityofevanston.org with any further questions or comments.

Sincerely,

John Gonzalez Purchasing Specialist



BID # 22-56

Sewer Inspection, 24-inch Diameter and Larger

ADDENDUM No. 1

September 12, 2022

This addendum forms a part of the Bid Documents for BID # 22-56 and modifies these documents. This addendum consists of the following:

BIDDER QUESTIONS:

1. QUESTION:

Can the Pipe Inspection be done with the "Boat" Method?

RESPONSE:

If the "Boat" Method or any other inspection method meets the contract requirements, then it will be allowed. Method of transporting the inspection equipment through the sewers shall meet the following requirements, as outlined in Technical Specifications, Equipment, A and B:

- A. "Inspection units shall contain a means of transporting the inspection equipment in a stable condition, above the flow line, through the sewer under inspection."
- B. "The location of the CCTV camera equipment shall be positioned at or near to the central axis of the sewer (centered horizontally and vertically)."

Note: Acknowledgment of this Addendum is required in the Bid.