



Bid #24 - 36

Water Treatment Chemicals

ADDENDUM No. 2

September 23, 2024

Any and all changes to the Bid are valid only if they are included by written addendum to all potential respondents, which will be emailed prior to the bid due date to all who are known to have received a complete Bid. Each respondent must acknowledge receipt of any addenda by indicating in its submission. Each respondent, by acknowledging receipt of addenda, is responsible for the contents of the addenda and any changes to the bid therein. Failure to acknowledge receipt of addenda may cause the submission to be rejected. If any language or figures contained in this addendum are in conflict with the original document, this addendum shall prevail.

This addendum consists of the following:

1. Addendum No.2 is attached and consists of a total of two (2) pages including this cover sheet.

Please contact me at 847-866-2910 or lithomas@cityofevanston.org with any further questions or comments.

Sincerely,

Linda Thomas
Purchasing Specialist



Bid #24 - 36

Water Treatment Chemicals

ADDENDUM No. 2

September 23, 2024

This addendum forms a part of the Bid Documents for Bid #24-36 and modifies these documents. This addendum consists of the following:

1. **Question:** I'm currently processing the chemical bid that is due on Oct 15, 2024. Per addendum 1, Polyaluminum Chloride was added to the Group A. Please confirm if the volume is correct for Polyaluminum Chloride has 575 per dry ton.

Answer: Yes

2. **Question:** In addendum 1 the City of Evanston calls for a PACL, which one (i.e., Material spec: % Al₂O₃; % Basicity)?

Answer:

SPECIFICATIONS

% Al ₂ O ₃	10.5 ± 0.5
% Al	5.6 ± 0.3
% Basicity	> 70
% Chloride	> 9.0

Note: Acknowledgment of this Addendum is required in the Submittal.